


TEST REPORT

CEI 0-21:2022-03

Reference technical rules for the connection of active and passive users to the LV electrical Utilities**Report Number**.....: 4905773.50**Date of issue**: 2023-06-28**Total number of pages** 78 pages**Testing Laboratory**: DEKRA Testing and Certification (Shanghai) Ltd., Guangzhou Branch**Address**.....: Block 5. No.3, Qiyun Road, Huangpu District, Guangzhou, Guangdong, China**Applicant**.....: EcoFlow Inc.**Applicant Address**: Plant A202, Founder Technology Industrial Park, Shiyan Sub-district, Bao'an District Shenzhen, Guangdong 518000 China**Standard**: CEI 0-21:2022-03**Test Report Form No.**: CEI 0-21_V2.1 (modified)**Test Report Form(s) Originator** ..: DEKRA Suzhou**Test item description**.....: Microinverter**Model/Type reference**.....: EFWN511, EFWN511B**Trade Mark**.....: **Manufacturer**: Same as applicant**Manufacturer Address**.....: Same as applicant**Prepared by**: Ray Ye (Project Manager)**Verified and approved by**: Among Chen (Technical Expert)

Summary of testing

Tests performed:

The following scope of assessment according to the standard: CEI 0-21:2022-03

Clause	Test	Result
A.3	Adjustable ranges of the interface protection system (SPI)	P
A.4.3.1 & A.4.3.2	Test procedure for maximum/minimum frequency functions (81.S2, 47.5~51.5 Hz)	P
A.4.3.1 & A.4.3.2	Test procedure for maximum/minimum frequency functions (81.S1, 49.8~50.2 Hz)	P
A.4.3.1 & A.4.3.2	Test procedure for maximum/minimum voltage functions (27.S2~59.S2, 0.15~1.15 Vn)	P
A.4.3.1 & A.4.3.2	Test procedure for maximum/minimum voltage functions (27.S1, 0.85 Vn)	P
A.4.3.1 & A.4.3.2	Measuring the rise-in voltage protection as a running 10-minute mean value (59.S1, 1.1 Vn)	P
A.4.3.3.1	Insensitivity to harmonics of the frequency relay (47.5Hz, 51.5Hz)	P
A.4.3.3.2	Remote trip signal	P
A.4.3.3.3	Communication signal	P
A.4.3.4	Verification of insensitivity to the frequency derivative	P
A.4.4	Self -test	P
A.4.5	Single fault tolerance	N/E
A.4.6	EMC compatibility tests	N/E
A.4.7	Climatic compatibility tests	P
A.4.8	Insulation tests	P
A.4.9	Tests for the overload capacity of measuring circuits	N/A
A.4.10	Compliance of equipment	P
A.4.11	Automatic mechanism to prevent current imbalance during production	P
B.1 (a)	Harmonic current	P
B.1 (c)	Voltage fluctuation and flicker	P
B.1.1	Conditions of connection, reconnection and gradual power supply	P
B.1.2.1	Verification of construction requirements: reactive power capability	P
B.1.2.2.1	Inverter in systems with total capacity (up to 11.08 kW)	P
B.1.2.2.2	Inverter in systems with total capacity (greater than 11.08 kW)	N/A
B.1.2.3.1	Procedures for performing tests and recording results (hypothesis of adjustment by Q) (greater than 11.08 kW)	N/A
B.1.2.4	Response time to an assigned step level change (greater than 11.08 kW)	N/A
B.1.2.5.1	Verification of compliance with the methods of application of the standard characteristic curve, $\cos\phi = f(P)$	P
B.1.2.6.1	Verification of compliance with the methods of application of the standard characteristic curve, $Q = f(V)$ (greater than 11.08 kW)	N/A
B.1.3.1	Automatic limitation of the active power for voltage values close to 110% of the	P

	rated voltage P(U)	
B.1.3.2	Adjusting active power in the presence of transients on the transmission network	P
B.1.3.3.1	Reduction of active power in the presence of under-frequency transients on transmission network	P
B.1.3.4	Limitation of the active power by an external control from the distributor	P
B.1.4.1	Verification of the emission of continuous component	N/A
B.1.4.2	Verification of the protections against the induction of a continuous component	N/A
B.1.5	Verification of insensitivity to voltage dips (UVRT capability, greater than 11.08 kW)	N/A
B.1.6.1	Verification of insensitivity to automatic reclosing in phase discrepancy (simulation network)	P
<p>Note:</p> <ul style="list-style-type: none"> - test case does not apply to the test object: N/A - test object was not evaluated for the requirement: N/E - test object does meet the requirement: P (Pass) 		

Performed tests:

All tests were performed under ISO/IEC 17025 accreditation on model EFWN511.

Date (s) of performance of tests: 2023-03-21 to 2023-06-27

Testing location:

EcoFlow Inc.

Plant A202, Founder Technology Industrial Park, Shiyan Sub-district, Bao'an District, Shenzhen, Guangdong, China

Conclusion:

The equipment under test complies with the following documents:

CEI 0-21:2022-03: Reference technical rules for the connection of active and passive users to the LV electrical Utilities

General remarks:

"(See Enclosure #)" refers to additional information appended to the report.

"(See appended table)" refers to a table appended to the report.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

The measurement result is considered in conformance with the requirement if it is within the prescribed limit. It is not necessary to account the uncertainty associated with the measurement result.

This report is only for reference and is not used for legal proof function in China market.

The information provided by the customer in this report may affect the validity of the results, the test lab is not responsible for it.

Throughout this report a comma / point is used as the decimal separator.


Product information

General:

The product is single-phase utility-interactive PV inverter, which converts DC power from the photovoltaic (PV) arrays as well as batteries to AC power. The battery port is able to be charged by the energy from PV port. The PCE does not provide galvanic separation between the PV input and battery circuit, but provides galvanic isolation from the AC output circuit.

The PV input combiner with 2 string MPPT tracers, which combines in one PV input terminal. AC output direct connected to grid and protective earthing are provided by dedicated earthing terminals. After the control system receives the abnormal signal from the relevant protective detection circuit, the redundant relays will operate to disconnect the PV inverter active lines from grid automatically.

Block diagram:



Model difference:

The model EFWN511B is identical with EFWN511 in hardware except the output power derated by software. Refer to the electrical rating.

Hardware & Software version

Hardware version	V4.0
Software version	V1.0

Factory:

Dongguan Streamax Electronics Co., Ltd.

101 Room, No.20 Building Leaguer Zijing Intelligent Manufacture Center, NO.105 Qingbin East Road, Qingxi Town, Dongguan City, Guangdong Province, China

Copy of marking plate:


EFWN511



EFWN511B

Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.

Specification of equipment under test:

Classification of installation and use: movable hand-held stationary
 fixed transportable for building-in

Supply connection: pluggable equipment direct plug-in
 permanent connection for building-in

Environmental category: outdoor indoor unconditional indoor conditional

Over voltage category Mains: OVC I OVC II OVC III OVC IV

Over voltage category PV: OVC I OVC II OVC III OVC IV

Mains supply tolerance (%): -15% to 10%

Tested for power systems: TN

IT testing, phase-phase voltage (V): N/A

Protective class: Class I Class II Class III

Mass of equipment (kg): Approximately 3 kg

Pollution degree: Outside PD3; Inside PD2

Operating temperature range: -40 °C to 50 °C

IP protection class: IP67

Power factor range: 0.8 leading...0.8 lagging (adjustable)

Electrical rating: EFWN511
 PV input: max 55 Vdc, MPPT voltage range 11-55 Vdc, max 13 A / 13 A, Isc PV 14 A / 14 A
 Battery: voltage range 30-58 Vdc, max current 13 A
 AC Output: L/N/PE, 220/230/240 Vac, 50 Hz, max 800 W, max 3.7 A
 EFWN511B
 PV input: max 55 Vdc, MPPT voltage range 11-55 Vdc, max 13 A / 13 A, Isc PV 14 A / 14 A
 Battery: voltage range 30-58 Vdc, max current 13 A
 AC Output: L/N/PE, 220/230/240 Vac, 50 Hz, max 600 W, max 2.8 A

Test setup:

The tests were performed using a PV simulator as a simulation of the PV module and a grid simulator as a simulation of the power grid and the transmission network. A simplified diagram of the test setup is given below. The measurement data were measured at POC at LV level.





Clause	Requirement + Test	Result - Remark	Verdict
A.3	Adjustment ranges for the SPI		P
A.3.1	Phase (or phase-to-phase) undervoltage protection [27]		P
	Minimum voltage threshold 27.S1: Threshold (0.2 ~ 1) Un r adjustable by steps of 0.05 Un Intervention time (0.05 ~ 5) s adjustable in steps of 0.05 s		P
	Minimum voltage threshold 27.S2: Threshold (0.05 ~ 1) Un adjustable by steps of 0.05 Un Intervention time (0.05 ~ 5) s adjustable in steps of 0.05 s		P
A.3.2	Maximum (or concatenated) phase voltage protection [59]		P
	Maximum voltage threshold 59.S1: Threshold (1 ~ 1.20) Un adjustable by steps of 0.01 Un Intervention time ≤ 3 s		P
	The overvoltage protection (59.S1) must be implemented as protection based on the calculation of the average value of 10 min according to the provisions of the EN 61000-4-30 standard. At the latest every 3 s, a new average value of the previous 10 min must be created, to be compared with the setting value for protection 59.S1 in Table 13.		P
	Maximum voltage threshold 59.S2: Threshold (1.0 ~ 1.30) Un adjustable by steps of 0.01 Un Intervention time (0.05 ~ 1) s adjustable in steps of 0.05 s		P
A.3.3	Minimum frequency protection [81<]		P
	Threshold 81<.S1: Threshold (47.0 ~ 50.0) Hz adjustable with step of 0.1 Hz Intervention time (0.05 ~ 5) s adjustable with step of 0.05 s		P
	Threshold 81<.S2: Threshold (47.0 ~ 50.0) Hz adjustable with step of 0.1 Hz Intervention time (0.05 ~ 5) s adjustable with step of 0.05 s		P
A.3.4	Maximum frequency protection [81>]		P
	Threshold 81>.S1: Threshold (50.0 ~ 52.0) Hz adjustable with step of 0.1 Hz Intervention time (0.05 ~ 5) s adjustable with step of 0.05 s		P
	Threshold 81>.S2: Threshold (50.0 ~ 52.0) Hz adjustable with step of 0.1 Hz Intervention time (0.05 ~ 5) s adjustable with step of 0.05 s		P
A.4.3	Functional tests on the interface protection system (SPI)		P
A.4.3.1	Test procedure for maximum voltage and frequency functions	See appended table	P
A.4.3.2	Test procedure for minimum voltage and frequency functions	See appended table	P
A.4.3.3	Additional requirements for functional tests	See appended table	P
A.4.3.3.1	Insensitivity to harmonics of the frequency relay	See appended table	P



A.4.3.3.2	Remote trip signal	See appended table	P
A.4.3.3.3	Communication signal	See appended table	P
A.4.3.4	Verification of insensitivity to the frequency derivative	See appended table	P
A.4.4	Self -test		P
	If the interface protection functions are integrated in the inverter, at least one self-test system must be provided which checks the maximum/minimum frequency and maximum/minimum voltage functions provided in the interface protection system (SPI).	See appended table	P
A.4.5	Single fault tolerance	See Enclosure #GZES221102245201 and #GZES221102245202	N/E
A.4.6	EMC compatibility tests	See Enclosure #18220WC30056802E	N/E
A.4.7	Climatic compatibility tests	See appended table	P
A.4.8	Insulation tests	See Enclosure #GZES221102245201	P
A.4.9	Tests for the overload capacity of measuring circuits	Internal SPI circuit for voltage protection.	N/A
A.4.10	Compliance of equipment		P
	The declaration of conformity must contain the results of all tests specified in A.4. In particular, all results related to the checking of tripping thresholds, falling times and falling ratios in all specified conditions must be provided.		P
	The tests were performed at a third-party laboratory accredited according to the CEI UNI EN ISO / IEC 17025 standard, or.		N/A
	at the manufacturer's laboratories, or non-accredited external laboratories under the supervision of a certification body accredited according to the CEI UNI EN ISO / IEC 17065 standard.		P
	It is also necessary to provide evidence that the production of the device takes place under a quality system (according to ISO 9001, see Annex 1 ISO 9001 certificate).		P
A.4.11	Automatic mechanism to prevent current imbalance during production	Single-phase equipment	N/A
B.1 (a)	Harmonic current	See appended table	P
B.1 (c)	Voltage fluctuation and flicker	See appended table	P
B.1.1	Conditions of connection, reconnection and gradual power supply		P
B.1.1.1	Checking of connection and reconnection conditions	See appended table	P
B.1.1.2	Checking gradual supply of active power	See appended table	P
B.1.2	Reactive power exchange		P
B.1.2.1	Checking construction standards: Reactive power capability		P


	As established in 8.4.4.2, static converters set up for continuous operation in parallel with the distributor network must be able to operate with a power factor different from 1.		P
	The converter must be set so that it can, respectively, absorb (induction) and supply (resistance) the maximum reactive power available at each level of active power supplied according to its capability.		P
	At this point the DC source must be regulated so that the converter can supply active power in sequence included in the 10 intervals [0-10%]; [10-20%]; [90-100]% of nominal power (1-min average values calculated on the basis of the values measured at the fundamental frequency in a 200-ms window).		P
	For each of the 10 levels of active power at least 3 values for inductive reactive power and 3 for capacitive power shall be reported as 1-min average values calculated based on measurements at the fundamental frequency of a 200-ms window.		P
	In addition to measurements of reactive power limit values, the measured values should be recorded by setting the reactive power supplied to 0 ($\cos \phi = 1$).		P
B.1.2.2	Methods of carrying out and recording the test	See appended table	P
B.1.2.2.1	Inverter in systems with total capacity (up to 11.08 kW)	See appended table	P
B.1.2.2.2	Inverter in systems with total capacity (greater than 11.08 kW)	Rating capacity 800 W	N/A
B.1.2.3	Exchange of reactive power according to an assigned level (greater than 11.08 kW)	Rating capacity 800 W	N/A
B.1.2.3.1	Procedures for performing tests and recording results (hypothesis of adjustment by Q) (greater than 11.08 kW)	Rating capacity 800 W	N/A
B.1.2.4	Response time to an assigned step level change (greater than 11.08 kW)	Rating capacity 800 W	N/A
B.1.2.5	Automatic supply of reactive power according to a characteristic curve, $\cos \phi = f(P)$		P
B.1.2.5.1	Verification of compliance with the methods of application of the standard characteristic curve, $\cos \phi = f(P)$	See appended table	P
B.1.2.6	Automatic exchange of reactive power according to a characteristic curve, $Q = f(V)$		N/A
B.1.2.6.1	Verification of compliance with the methods of application of the standard characteristic curve, $Q = f(V)$ (greater than 11.08 kW)	Rating capacity 800 W	N/A
B.1.3	Limitation of active power		P
B.1.3.1	Automatic limitation of the active power for voltage values close to 110% of the rated voltage $P(U)$	See appended table	P
B.1.3.2	Adjusting active power in the presence of transients on the transmission network	See appended table	P
B.1.3.3	Verification of the operating range in voltage and frequency	See appended table	P
B.1.3.3.1	Reduction of active power in the presence of under-frequency transients on transmission network	See appended table	P

B.1.3.4	Limitation of the active power by an external control from the distributor	See appended table	P
B.1.4	Output of DC component in the output current		N/A
B.1.4.1	Verification of the emission of continuous component	Isolated equipment	N/A
B.1.4.2	Verification of the protections against the induction of a continuous component	Isolated equipment	N/A
B.1.5	Verification of insensitivity to voltage dips (UVRT capability, greater than 11.08 kW)	Rating capacity 800 W	N/A
B.1.6	Checking the insensitivity to automatic reclosing during phase accordance		P
B.1.6.1	Test on the simulation network	See appended table	P
B.1.6.2	Test on the distribution network by means of a coupling transformer	By simulation network	N/A
B.1.6.3	Distribution network test, frequency drift simulation	By simulation network	N/A
B.1.6.4	Extension of results		P



A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum frequency functions (81.S2, 47.5~51.5 Hz)					P					
Model: EFWN511											
	Under frequency: 81<.S2				Over frequency: 81>.S2						
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps				0.99 threshold -> increase by max 10mHz steps						
D) STEP for trip time [Hz to Hz]:	1.01 threshold -> 0.99 threshold				0.99 threshold -> 1.01 threshold						
Ambient condition 25 °C											
Tripping threshold limit [Hz]:	47.50 (47.48–47.52)			51.50 (51.48–51.52)							
Measurement accuracy of the tripping value [Hz]:	47.493	47.490	47.492	51.503	51.510	51.513					
Trip time limit [ms]:	100 (77–123)			100 (77–123)							
Measurement the trip time [ms]:	89.8	80.6	92.0	94.8	104.4	103.6					
Ambient condition -10 °C											
Tripping threshold limit [Hz]:	47.50 (47.48–47.52)			51.50 (51.48–51.52)							
Measurement accuracy of the tripping value [Hz]:	47.502	47.490	--	51.515	51.504	--					
Trip time limit [ms]:	100 (77–123)			100 (77–123)							
Measurement the trip time [ms]:	98.0	110.2	--	101.8	93.4	--					
Ambient condition 50 °C											
Tripping threshold limit [Hz]:	47.50 (47.48–47.52)			51.50 (51.48–51.52)							
Measurement accuracy of the tripping value [Hz]:	47.494	--	--	51.505	--	--					
Trip time limit [ms]:	100 (77–123)			100 (77–123)							
Measurement the trip time [ms]:	113.8	--	--	105.4	--	--					
Test:											
To measure the disconnection time a step of $1\%f_n$ is taken from the nominal frequency for underfrequency and overfrequency.											
Assessment criterion:											
For frequencies of between 47.5 Hz and 51.5 Hz ($\pm 0.1\% f_n$) automatic disconnection from the network as a result of a deviation in frequency is not permitted.											
Limit values:											
Frequency decrease protection		$f < 47.5 \text{ Hz}, 100 \text{ ms}$									
Frequency increase protection		$f < 51.5 \text{ Hz}, 100 \text{ ms}$									
For each repetition of the tests, the max tolerances of the values are:											
Voltage: 2%											
Frequency: $\pm 20 \text{ mHz}$											
Trip times: $1\% \pm 20 \text{ ms}$											
Note:											
The tests were performed on EFWN511 and are also applicable for all other models stated in this report.											












A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum frequency functions (81.S1, 49.8~50.2 Hz)					P					
Model: EFWN511											
	Under frequency: 81<.S1				Over frequency: 81>.S1						
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps				0.99 threshold -> increase by max 10mHz steps						
D) STEP for trip time [Hz to Hz]:	1.01 threshold -> 0.99 threshold				0.99 threshold -> 1.01 threshold						
Ambient condition 25 °C											
Tripping threshold limit [Hz]:	49.80 (49.78–49.82)				50.20 (50.18–50.22)						
Measurement accuracy of the tripping value [Hz]:	49.793	49.792	49.792	50.203	50.202	50.211					
Trip time limit [ms]:	100 (77–123)				100 (77–123)						
Measurement the trip time [ms]:	97.0	100.4	110.8	107.2	113.2	100.0					
Ambient condition -10 °C											
Tripping threshold limit [Hz]:	49.80 (49.78–49.82)				50.20 (50.18–50.22)						
Measurement accuracy of the tripping value [Hz]:	49.792	49.793	--	50.203	50.204	--					
Trip time limit [ms]:	100 (77–123)				100 (77–123)						
Measurement the trip time [ms]:	109.8	105.6	--	108.8	109.0	--					
Ambient condition 50 °C											
Tripping threshold limit [Hz]:	49.80 (49.78–49.82)				50.20 (50.18–50.22)						
Measurement accuracy of the tripping value [Hz]:	49.793	--	--	50.204	--	--					
Trip time limit [ms]:	100 (77–123)				100 (77–123)						
Measurement the trip time [ms]:	97.0	--	--	106.6	--	--					
Test:											
To measure the disconnection time a step of 1%fn is taken from the nominal frequency for underfrequency and overfrequency.											
Assessment criterion:											
For frequencies of between 47.5 Hz and 51.5 Hz ($\pm 0.1\% f_n$) automatic disconnection from the network as a result of a deviation in frequency is not permitted.											
Limit values:											
Frequency decrease protection		$f < 47.5 \text{ Hz}$, 100 ms									
Frequency increase protection		$f < 51.5 \text{ Hz}$, 100 ms									
For each repetition of the tests, the max tolerances of the values are:											
Voltage: 2%											
Frequency: $\pm 20 \text{ mHz}$											
Trip times: $1\% \pm 20 \text{ ms}$											
Note:											
The tests were performed on EFWN511 and are also applicable for all other models stated in this report.											











A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum voltage functions (27.S2~59.S2, 0.15~1.15 Vn)					P
Model: EFWN511		Phase: single				
	Under voltage: 27.S2			Over voltage: 59.S2		
A) STEPS for trip value [V to V]:	1.1 threshold -> decrease by max 5V steps			0.9 threshold -> increase by max 5V steps		
Ambient condition 25 °C						
Tripping threshold limit [V]:	34.5 (32.2–36.8)			264.5 (262.2–266.8)		
Measurement accuracy of the tripping value [V]:	34.0	33.8	33.4	263.6	264.0	263.8
Trip time limit [ms]:	200 (174–226)			200 (174–226)		
Measurement the trip time [ms]:	180.0	184.8	185.6	213.6	203.2	194.8
Ambient condition -10 °C						
Tripping threshold limit [V]:	34.5 (32.2–36.8)			264.5 (262.2–266.8)		
Measurement accuracy of the tripping value [V]:	33.58	33.08	--	263.58	264.35	--
Trip time limit [ms]:	200 (174–226)			200 (174–226)		
Measurement the trip time [ms]:	205.0	189.2	--	217.4	217.9	--
Ambient condition 50 °C						
Tripping threshold limit [V]:	34.5 (32.2–36.8)			264.5 (262.2–266.8)		
Measurement accuracy of the tripping value [V]:	33.72	--	--	264.55	--	--
Trip time limit [ms]:	200 (174–226)			200 (174–226)		
Measurement the trip time [ms]:	204.6	--	--	210.0	--	--
Test: To measure the disconnection time a step of 15%U _n for undervoltage and of 115%U _n for overvoltage. The voltages should be measured per phase conductor, in which current is fed between the line conductor and the neutral conductor.						
Assessment criterion:						
<u>Limit values:</u>						
Voltage drop protection	27.S2	/ 0.15 U _n	/ 200 ms			
Rise-in voltage protection	59.S2	/ 1.15 U _n	/ 200 ms			
The setting value and the trip value of the frequency may not vary by more than ≤5%V _n and 3%±20ms.						
For each repetition of the tests, the max tolerances of the values are:						
Voltage: 2%						
Frequency: ±20mHz						
Trip times: 1%±20ms						
Note: The tests were performed on EFWN511 and are also applicable for all other models stated in this report.						









A.4.3.1 & A.4.3.2	TABLE: Test procedure for maximum/minimum voltage functions (27.S1, 0.85 Vn)								P
Model: EFWN511	Phase: single								
	Under voltage: 27.S1								
A) STEPS for trip value [V to V]:	1.1 threshold -> decrease by max 5V steps								
D) STEP for trip time [V to V]:	1.1 threshold -> 0.9 threshold								
Ambient condition	25 °C			-10 °C			50 °C		
Tripping threshold limit [V]:	195.5 (193.2–197.8)								
Measurement accuracy of the tripping value [V]:	195.2	195.1	195.2	194.95	194.64	--	194.85	--	--
Trip time limit [ms]:	1500 (1435–1565)								
Measurement the trip time [ms]:	1541	1542	1540	1522	1537	--	1521	--	--
Test:	To measure the disconnection time a step of 85%U _n for undervoltage. The voltages should be measured per phase conductor, in which current is fed between the line conductor and the neutral conductor.								
Assessment criterion:									
<u>Limit values:</u>									
Voltage drop protection 27.S1 / 0.85 U _n / 1500 ms									
The setting value and the trip value of the frequency may not vary by more than ≤5%V _n and 3%±20ms.									
For each repetition of the tests, the max tolerances of the values are:									
Voltage: 2%									
Frequency: ±20mHz									
Trip times: 1%±20ms									
Note:	The tests were performed on EFWN511 and are also applicable for all other models stated in this report.								







A.4.3.1 & A.4.3.2		TABLE: Measuring the rise-in voltage protection as a running 10-minute mean value (59.S1, 1.10 Vn)		P		
Model: EFWN511						
Test:		Disconnection time:	Limit:			
a)		The voltage is set to 100% U_n and held for 600 s. Thereafter the voltage is set to 112% U_n . Disconnection must take place within 600 s.				
a)	Phase A	586.0	≤ 600 s			
	Phase B	--				
	Phase C	--				
b)		The voltage is set to 100% U_n for 600 s and then to 108% U_n for 600 s. No disconnection should take place.				
b)	Phase A	No disconnection	Disconnection should not take place.			
	Phase B	--				
	Phase C	--				
c)		The voltage is set to 106 % U_n and held for 600 s. Thereafter the voltage is set to 114 % U_n . Disconnection must take place within 300 s or about 50 % of the disconnection time measured in point a).*	The disconnection time should be about 50 % of the value measured in a). *			
c)	Phase A	255.8				
	Phase B	--				
	Phase C	--				
Note:						
*If the setting value is set to 600 s, then disconnection time can be in the range between 225 s and 375 s. The tests were performed on EFWN511 and are also applicable for all other models stated in this report.						





Graph of b) 100%Un to 108%Un (25 °C)





Graph of c) 106 % Un to 114%Un (25 °C)



A.4.3.3.1	TABLE: Insensitivity to harmonics of the frequency relay (47.5Hz, 51.5Hz)					P
Model: EFWN511						
	Under frequency: 81<.S1			Over frequency: 81>.S1		
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps			0.99 threshold -> increase by max 10mHz steps		
D) STEP trip time [Hz to Hz]:	1.01 threshold -> 0.99 threshold			0.99 threshold -> 1.01 threshold		
Tripping threshold limit [Hz]:	49.80 (49.78–49.82)			50.20 (50.18–50.22)		
Measurement accuracy of the tripping value [Hz]:	49.790	--	--	50.205	--	--
Trip time limit [ms]:	100 (77–123)			100 (77–123)		
Measurement the trip time [ms]:	120.6	--	--	108.6	--	--
	Under frequency: 81<.S2			Over frequency: 81>.S2		
A) STEPS for trip value [Hz to Hz]:	1.01 threshold -> decrease by max 10mHz steps			0.99 threshold -> increase by max 10mHz steps		
D) STEP trip time [Hz to Hz]:	1.01 threshold -> 0.99 threshold			0.99 threshold -> 1.01 threshold		
Tripping threshold limit [Hz]:	47.50 (47.48–47.52)			51.50 (51.48–51.52)		
Measurement accuracy of the tripping value [Hz]:	47.491	--	--	51.504	--	--
Trip time limit [ms]:	100 (77–123)			100 (77–123)		
Measurement the trip time [ms]:	117.2	--	--	106.6	--	--
Test:	The harmonics, which voltage waveform distorted as required by <i>Table 17 – Harmonics for the insensitivity of the frequency protection function</i> , were applied at the a.c. terminals in order to check the trip time and trip values of the protections.					
Note:	The setting value and the trip value of the frequency may not vary by more than ±20mHz and 3%±20ms . Differences between the test values: ±20mHz and 1%±20ms .					
The tests were performed on EFWN511 and are also applicable for all other models stated in this report.						






A.4.3.3.2	TABLE: Remote trip signal	P
Model: EFWN511		
Test:	Remote tripping signal for the external disconnection	
Limit [ms]:	50	
Reaction time of the tripping value [ms]:	22.2	

Note:


The protection interface has to have a maximum delay of the remote tripping signal from receiving to transmitting to the DDI of 50ms.

The tests were performed on EFWN511 and are also applicable for all other models stated in this report.

Screenshot of remote trip signal



A.4.3.3.3	TABLE: Communication Signal	P
Model: EFWN511		
Test at standard conditions	Threshold value	Input signal value
External signal ON	Set: 47.50 Hz	47.49 Hz
External signal OFF	Set: 49.80 Hz	49.79 Hz
External signal ON	Set: 51.50 Hz	51.51 Hz
External signal OFF	Set: 50.20 Hz	51.21 Hz
Test:	It is checked that the selection of frequency protections is performed with an external signal via USB.	
Note:	The tests were performed on EFWN511 and are also applicable for all other models stated in this report.	

A.4.3.4		TABLE: Verification of insensitivity to the frequency derivative		P
Model: EFWN511				
No.	Test	Trip		
1)	Positive slope (47.57 Hz to 51.44 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
2)	Negative slope (51.44 Hz to 47.57 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
3)	Positive slope (47.57 Hz to 51.44 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
4)	Negative slope (51.44 Hz to 47.57 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
5)	Positive slope (47.57 Hz to 51.44 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
6)	Negative slope (51.44 Hz to 47.57 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
7)	Positive slope (47.57 Hz to 51.44 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
8)	Negative slope (51.44 Hz to 47.57 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
9)	Positive slope (47.57 Hz to 51.44 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
10)	Negative slope (51.44 Hz to 47.57 Hz)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Test:				
Frequency protection settings as following: 81>: tripping threshold 51.5 Hz, tripping time 0.15 s 81<: intervention threshold 47.5 Hz, tripping time 0.15 s				
Test procedure as following: 1) Working at 100%Un and 47.550Hz; 2) Increase the frequency with ramp steps having an amplitude equal to 12.5 mHz and duration 5 ms, until reaching the frequency value of 51.450 Hz (*) ; 3) Decrease the frequency with ramp steps having an amplitude equal to 12.5 mHz and duration 5 ms, until reaching the frequency value of 47.550Hz (*) ; 4) repeat the tests described in points 2 and 3 above for four times, for a total of 5 positive and negative ramps.				
The test is considered to be passed in the absence of minimum and maximum frequency protection trips. If the SPI is integrated in the inverter, in addition to the absence of minimum and maximum frequency protection trips, it must also be verified that the inverter continues to operate. (*) These ramp settings produce a frequency derivative of $12.5 \text{ mHz} / 5 \text{ ms} = 2.5 \text{ Hz/s}$				
Note: The tests were performed on EFWN511 and are also applicable for all other models stated in this report.				
<p style="text-align: center;">Graph of insensitivity to the frequency derivative</p> 				

A.4.4		TABLE: Self -test	P
No.	Item	Result	
1)	for each frequency and voltage protection function, the tripping threshold varies linearly upward or downward with a slope of $\leq 0.05 \text{ Hz/s}$ or $\leq 0.05 \text{ Vn/s}$ respectively for the frequency and voltage protection;	Pass	
2)	This will determine, at a certain point in the test, whether the threshold and the actual value of the controlled parameter (frequency or voltage) coincide, and thus whether the protection was triggered and the interface device subsequently opened.	Pass	
3)	For each test, the person conducting the test must be able to view the quantity and trip time values, in addition to the current value of the voltage and frequency detected by the converter.	Pass	
4)	The tests must measure the: <ul style="list-style-type: none"> • accuracy of tripping thresholds; • accuracy of trip times. 	Pass	
5)	After each test, the inverter must exit the test mode, reset the normally used settings and automatically reconnect to the network when the conditions are appropriate.	Pass	
6)	Any user must be able to activate the procedure and it must be clearly described in the converter user manual.	Pass	

Note:
The tests were performed on EFWN511 and are also applicable for all other models stated in this report.

A.4.7	TABLE: Climatic compatibility tests			P			
Model: EFWN511							
Equipment not powered							
Temperature	Relative humidity	Standards	Test time				
70°C ± 2°C	--	EN 60068-2-2	16h				
40°C ± 2°C	93% ± 3%	EN 60068-2-78	4 days				
-10°C ± 2°C	--	EN 60068-2-1	16h				
-10°C -> +70°C ± 2°C	--	EN 60068-2-14	3h @ -10°C, 3h @ +70°C				
Equipment powered							
Temperature	Relative humidity	Standards	Test time				
50°C ± 2°C	--	EN 60068-2-2	16h				
40°C ± 2°C	93% ± 3%	EN 60068-2-78	4 days				
-10°C ± 2°C	--	EN 60068-2-1	16h				
-10°C -> +50°C ± 2°C	--	EN 60068-2-14	3h @ -10°C, 3h @ +50°C				
Note:							
During and at the end of the test the sample does not have any damage.							
For the verification of the following during the climatic tests, see TABLE A.4.3.1 & A.4.3.2.							
The tests were performed on EFWN511 and are also applicable for all other models stated in this report.							

A.4.9	Tests for the overload capacity of measuring circuits		N/A
Model: EFWN511			
Voltage	Test time	Result:	
≥130%U _N	1 min		
≥150%U _N	1s		
Note:			
The unit is not allowed to be damaged while testing. The measurement circuit must show after the test the same values like before the test.			

A.4.11	Automatic mechanism to prevent current imbalance during production		N/A		
Model:					
Test 1					
Imbalance of power:	Test time:	Limit:			
<10kW		max. 30 min			
Test 2					
Imbalance of power:	Test time:	Limit:			
>10kW		max. 1 min			
Note:					
Test 1 must only be performed, if the system can produce an imbalance less than 10kW.					
Test 1 and Test 2 must be performed, if the system can produce an imbalance more than 10kW.					

B.1 (a)		TABLE: Harmonic current								P								
Model: EFWN511																		
Order no.	Ambient condition 25 °C									Current Limits (A)								
	Current Magnitude (A)																	
	Output 100%Pn			Output 66%Pn			Output 33%Pn											
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
1	--	--	--	--	--	--	--	--	--	--								
2	0.175	--	--	0.116	--	--	0.059	--	--	1.080								
3	0.080	--	--	0.054	--	--	0.030	--	--	2.300								
4	0.056	--	--	0.040	--	--	0.023	--	--	0.430								
5	0.041	--	--	0.027	--	--	0.014	--	--	1.140								
6	0.041	--	--	0.029	--	--	0.015	--	--	0.300								
7	0.030	--	--	0.020	--	--	0.010	--	--	0.770								
8	0.028	--	--	0.019	--	--	0.009	--	--	0.230								
9	0.022	--	--	0.015	--	--	0.008	--	--	0.400								
10	0.021	--	--	0.013	--	--	0.007	--	--	0.184								
11	0.020	--	--	0.013	--	--	0.006	--	--	0.330								
12	0.017	--	--	0.011	--	--	0.006	--	--	0.153								
13	0.016	--	--	0.011	--	--	0.007	--	--	0.210								
14	0.014	--	--	0.010	--	--	0.005	--	--	0.131								
15	0.014	--	--	0.009	--	--	0.005	--	--	0.150								
16	0.013	--	--	0.009	--	--	0.005	--	--	0.115								
17	0.012	--	--	0.008	--	--	0.005	--	--	0.132								
18	0.011	--	--	0.008	--	--	0.004	--	--	0.102								
19	0.011	--	--	0.007	--	--	0.004	--	--	0.118								
20	0.011	--	--	0.008	--	--	0.005	--	--	0.092								
21	0.010	--	--	0.007	--	--	0.004	--	--	0.107								
22	0.010	--	--	0.007	--	--	0.004	--	--	0.084								
23	0.009	--	--	0.006	--	--	0.003	--	--	0.098								
24	0.010	--	--	0.007	--	--	0.004	--	--	0.077								
25	0.008	--	--	0.006	--	--	0.003	--	--	0.090								
26	0.008	--	--	0.006	--	--	0.003	--	--	0.071								
27	0.008	--	--	0.005	--	--	0.003	--	--	0.083								
28	0.008	--	--	0.005	--	--	0.003	--	--	0.066								
29	0.007	--	--	0.005	--	--	0.003	--	--	0.078								
30	0.007	--	--	0.005	--	--	0.003	--	--	0.061								
31	0.007	--	--	0.005	--	--	0.003	--	--	0.073								
32	0.007	--	--	0.004	--	--	0.002	--	--	0.058								
33	0.006	--	--	0.004	--	--	0.002	--	--	0.068								
34	0.006	--	--	0.004	--	--	0.002	--	--	0.054								
35	0.006	--	--	0.004	--	--	0.002	--	--	0.064								
36	0.006	--	--	0.004	--	--	0.002	--	--	0.051								
37	0.006	--	--	0.004	--	--	0.002	--	--	0.061								
38	0.005	--	--	0.004	--	--	0.002	--	--	0.048								
39	0.005	--	--	0.004	--	--	0.002	--	--	0.058								
40	0.005	--	--	0.004	--	--	0.002	--	--	0.046								

Note:
 Each phase output current ≤ 16A, it shall be complied with EN 61000-3-2.
 The tests were performed on both EFWN511 and EFWN511B.

B.1 (a)		TABLE: Harmonic current								P								
Model: EFWN511																		
Order no.	Ambient condition -10 °C									Current Limits (A)								
	Current Magnitude (A)			Output 100%Pn			Output 66%Pn											
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
1	--	--	--	--	--	--	--	--	--	--								
2	0.117	--	--	0.077	--	--	0.039	--	--	1.080								
3	0.053	--	--	0.036	--	--	0.020	--	--	2.300								
4	0.037	--	--	0.027	--	--	0.016	--	--	0.430								
5	0.027	--	--	0.018	--	--	0.009	--	--	1.140								
6	0.027	--	--	0.019	--	--	0.010	--	--	0.300								
7	0.020	--	--	0.013	--	--	0.007	--	--	0.770								
8	0.018	--	--	0.013	--	--	0.006	--	--	0.230								
9	0.015	--	--	0.010	--	--	0.005	--	--	0.400								
10	0.014	--	--	0.009	--	--	0.004	--	--	0.184								
11	0.014	--	--	0.008	--	--	0.004	--	--	0.330								
12	0.011	--	--	0.008	--	--	0.004	--	--	0.153								
13	0.011	--	--	0.007	--	--	0.005	--	--	0.210								
14	0.010	--	--	0.006	--	--	0.003	--	--	0.131								
15	0.009	--	--	0.006	--	--	0.004	--	--	0.150								
16	0.008	--	--	0.006	--	--	0.003	--	--	0.115								
17	0.008	--	--	0.006	--	--	0.003	--	--	0.132								
18	0.008	--	--	0.005	--	--	0.003	--	--	0.102								
19	0.007	--	--	0.005	--	--	0.003	--	--	0.118								
20	0.007	--	--	0.005	--	--	0.003	--	--	0.092								
21	0.006	--	--	0.005	--	--	0.002	--	--	0.107								
22	0.007	--	--	0.005	--	--	0.003	--	--	0.084								
23	0.006	--	--	0.004	--	--	0.002	--	--	0.098								
24	0.006	--	--	0.005	--	--	0.003	--	--	0.077								
25	0.006	--	--	0.004	--	--	0.002	--	--	0.090								
26	0.005	--	--	0.004	--	--	0.002	--	--	0.071								
27	0.005	--	--	0.004	--	--	0.002	--	--	0.083								
28	0.005	--	--	0.003	--	--	0.002	--	--	0.066								
29	0.005	--	--	0.004	--	--	0.002	--	--	0.078								
30	0.005	--	--	0.003	--	--	0.002	--	--	0.061								
31	0.005	--	--	0.003	--	--	0.002	--	--	0.073								
32	0.004	--	--	0.003	--	--	0.002	--	--	0.058								
33	0.004	--	--	0.003	--	--	0.002	--	--	0.068								
34	0.004	--	--	0.003	--	--	0.002	--	--	0.054								
35	0.004	--	--	0.003	--	--	0.002	--	--	0.064								
36	0.004	--	--	0.003	--	--	0.001	--	--	0.051								
37	0.004	--	--	0.003	--	--	0.001	--	--	0.061								
38	0.004	--	--	0.003	--	--	0.001	--	--	0.048								
39	0.003	--	--	0.002	--	--	0.001	--	--	0.058								
40	0.003	--	--	0.002	--	--	0.001	--	--	0.046								

Note:
 Each phase output current ≤ 16A, it shall be complied with EN 61000-3-2.
 The tests were performed on both EFWN511 and EFWN511B.

B.1 (a)		TABLE: Harmonic current								P								
Model: EFWN511																		
Order no.	Ambient condition 50 °C									Current Limits (A)								
	Current Magnitude (A)			Output 100%Pn			Output 66%Pn											
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
1	--	--	--	--	--	--	--	--	--	--								
2	0.175	--	--	0.116	--	--	0.059	--	--	1.080								
3	0.080	--	--	0.054	--	--	0.030	--	--	2.300								
4	0.056	--	--	0.040	--	--	0.023	--	--	0.430								
5	0.041	--	--	0.028	--	--	0.014	--	--	1.140								
6	0.041	--	--	0.028	--	--	0.015	--	--	0.300								
7	0.030	--	--	0.020	--	--	0.010	--	--	0.770								
8	0.028	--	--	0.019	--	--	0.009	--	--	0.230								
9	0.023	--	--	0.015	--	--	0.008	--	--	0.400								
10	0.021	--	--	0.013	--	--	0.007	--	--	0.184								
11	0.021	--	--	0.012	--	--	0.006	--	--	0.330								
12	0.017	--	--	0.011	--	--	0.006	--	--	0.153								
13	0.016	--	--	0.011	--	--	0.007	--	--	0.210								
14	0.014	--	--	0.010	--	--	0.005	--	--	0.131								
15	0.014	--	--	0.009	--	--	0.005	--	--	0.150								
16	0.013	--	--	0.009	--	--	0.005	--	--	0.115								
17	0.012	--	--	0.009	--	--	0.005	--	--	0.132								
18	0.011	--	--	0.008	--	--	0.005	--	--	0.102								
19	0.011	--	--	0.007	--	--	0.004	--	--	0.118								
20	0.011	--	--	0.007	--	--	0.005	--	--	0.092								
21	0.010	--	--	0.006	--	--	0.004	--	--	0.107								
22	0.010	--	--	0.007	--	--	0.004	--	--	0.084								
23	0.009	--	--	0.006	--	--	0.003	--	--	0.098								
24	0.009	--	--	0.007	--	--	0.004	--	--	0.077								
25	0.009	--	--	0.006	--	--	0.003	--	--	0.090								
26	0.008	--	--	0.006	--	--	0.003	--	--	0.071								
27	0.008	--	--	0.006	--	--	0.003	--	--	0.083								
28	0.007	--	--	0.005	--	--	0.003	--	--	0.066								
29	0.008	--	--	0.005	--	--	0.003	--	--	0.078								
30	0.007	--	--	0.005	--	--	0.003	--	--	0.061								
31	0.007	--	--	0.005	--	--	0.003	--	--	0.073								
32	0.006	--	--	0.005	--	--	0.002	--	--	0.058								
33	0.006	--	--	0.004	--	--	0.002	--	--	0.068								
34	0.006	--	--	0.004	--	--	0.002	--	--	0.054								
35	0.006	--	--	0.004	--	--	0.002	--	--	0.064								
36	0.006	--	--	0.004	--	--	0.002	--	--	0.051								
37	0.006	--	--	0.004	--	--	0.002	--	--	0.061								
38	0.005	--	--	0.004	--	--	0.002	--	--	0.048								
39	0.005	--	--	0.004	--	--	0.002	--	--	0.058								
40	0.005	--	--	0.004	--	--	0.002	--	--	0.046								

Note:
Each phase output current ≤ 16A, it shall be complied with EN 61000-3-2.
The tests were performed on both EFWN511 and EFWN511B.

B.1 (a)		TABLE: Harmonic current								P								
Model: EFWN511B																		
Order no.	Ambient condition 25 °C									Current Limits (A)								
	Current Magnitude (A)																	
	Output 100%Pn			Output 66%Pn			Output 33%Pn											
L1	L2	L3	L1	L2	L3	L1	L2	L3										
1	--	--	--	--	--	--	--	--	--	--								
2	0.021	--	--	0.018	--	--	0.018	--	--	1.080								
3	0.081	--	--	0.064	--	--	0.045	--	--	2.300								
4	0.005	--	--	0.005	--	--	0.006	--	--	0.430								
5	0.043	--	--	0.029	--	--	0.014	--	--	1.140								
6	0.005	--	--	0.005	--	--	0.004	--	--	0.300								
7	0.022	--	--	0.008	--	--	0.008	--	--	0.770								
8	0.004	--	--	0.003	--	--	0.004	--	--	0.230								
9	0.010	--	--	0.006	--	--	0.009	--	--	0.400								
10	0.004	--	--	0.004	--	--	0.003	--	--	0.184								
11	0.005	--	--	0.004	--	--	0.009	--	--	0.330								
12	0.004	--	--	0.004	--	--	0.004	--	--	0.153								
13	0.006	--	--	0.009	--	--	0.009	--	--	0.210								
14	0.004	--	--	0.004	--	--	0.003	--	--	0.131								
15	0.006	--	--	0.008	--	--	0.007	--	--	0.150								
16	0.003	--	--	0.004	--	--	0.004	--	--	0.115								
17	0.007	--	--	0.008	--	--	0.007	--	--	0.132								
18	0.004	--	--	0.004	--	--	0.004	--	--	0.102								
19	0.006	--	--	0.006	--	--	0.005	--	--	0.118								
20	0.004	--	--	0.003	--	--	0.003	--	--	0.092								
21	0.008	--	--	0.007	--	--	0.005	--	--	0.107								
22	0.003	--	--	0.003	--	--	0.003	--	--	0.084								
23	0.007	--	--	0.006	--	--	0.007	--	--	0.098								
24	0.004	--	--	0.003	--	--	0.004	--	--	0.077								
25	0.005	--	--	0.005	--	--	0.007	--	--	0.090								
26	0.004	--	--	0.004	--	--	0.003	--	--	0.071								
27	0.005	--	--	0.006	--	--	0.006	--	--	0.083								
28	0.005	--	--	0.004	--	--	0.004	--	--	0.066								
29	0.006	--	--	0.005	--	--	0.007	--	--	0.078								
30	0.005	--	--	0.006	--	--	0.005	--	--	0.061								
31	0.007	--	--	0.006	--	--	0.006	--	--	0.073								
32	0.005	--	--	0.005	--	--	0.004	--	--	0.058								
33	0.006	--	--	0.007	--	--	0.006	--	--	0.068								
34	0.005	--	--	0.005	--	--	0.005	--	--	0.054								
35	0.006	--	--	0.007	--	--	0.008	--	--	0.064								
36	0.007	--	--	0.005	--	--	0.006	--	--	0.051								
37	0.007	--	--	0.006	--	--	0.007	--	--	0.061								
38	0.006	--	--	0.006	--	--	0.005	--	--	0.048								
39	0.007	--	--	0.007	--	--	0.008	--	--	0.058								
40	0.006	--	--	0.005	--	--	0.005	--	--	0.046								

Note:
Each phase output current ≤ 16A, it shall be complied with EN 61000-3-2.
The tests were performed on both EFWN511 and EFWN511B.

B.1 (a)		TABLE: Harmonic current								P								
Model: EFWN511B																		
Order no.	Ambient condition -10 °C									Current Limits (A)								
	Current Magnitude (A)																	
	Output 100%Pn			Output 66%Pn			Output 33%Pn											
L1	L2	L3	L1	L2	L3	L1	L2	L3										
1	--	--	--	--	--	--	--	--	--	--								
2	0.019	--	--	0.019	--	--	0.018	--	--	1.080								
3	0.080	--	--	0.063	--	--	0.043	--	--	2.300								
4	0.005	--	--	0.005	--	--	0.006	--	--	0.430								
5	0.042	--	--	0.029	--	--	0.013	--	--	1.140								
6	0.004	--	--	0.004	--	--	0.005	--	--	0.300								
7	0.022	--	--	0.007	--	--	0.008	--	--	0.770								
8	0.003	--	--	0.003	--	--	0.004	--	--	0.230								
9	0.009	--	--	0.006	--	--	0.008	--	--	0.400								
10	0.003	--	--	0.003	--	--	0.003	--	--	0.184								
11	0.005	--	--	0.004	--	--	0.009	--	--	0.330								
12	0.005	--	--	0.004	--	--	0.004	--	--	0.153								
13	0.005	--	--	0.007	--	--	0.008	--	--	0.210								
14	0.004	--	--	0.003	--	--	0.003	--	--	0.131								
15	0.006	--	--	0.008	--	--	0.007	--	--	0.150								
16	0.003	--	--	0.003	--	--	0.003	--	--	0.115								
17	0.008	--	--	0.007	--	--	0.007	--	--	0.132								
18	0.003	--	--	0.003	--	--	0.004	--	--	0.102								
19	0.005	--	--	0.005	--	--	0.005	--	--	0.118								
20	0.003	--	--	0.003	--	--	0.003	--	--	0.092								
21	0.007	--	--	0.006	--	--	0.005	--	--	0.107								
22	0.003	--	--	0.002	--	--	0.003	--	--	0.084								
23	0.006	--	--	0.006	--	--	0.007	--	--	0.098								
24	0.004	--	--	0.003	--	--	0.003	--	--	0.077								
25	0.006	--	--	0.006	--	--	0.006	--	--	0.090								
26	0.003	--	--	0.004	--	--	0.003	--	--	0.071								
27	0.005	--	--	0.005	--	--	0.006	--	--	0.083								
28	0.004	--	--	0.004	--	--	0.004	--	--	0.066								
29	0.005	--	--	0.005	--	--	0.006	--	--	0.078								
30	0.005	--	--	0.004	--	--	0.004	--	--	0.061								
31	0.006	--	--	0.004	--	--	0.006	--	--	0.073								
32	0.005	--	--	0.005	--	--	0.005	--	--	0.058								
33	0.005	--	--	0.006	--	--	0.006	--	--	0.068								
34	0.004	--	--	0.005	--	--	0.004	--	--	0.054								
35	0.008	--	--	0.007	--	--	0.007	--	--	0.064								
36	0.006	--	--	0.005	--	--	0.005	--	--	0.051								
37	0.007	--	--	0.007	--	--	0.008	--	--	0.061								
38	0.004	--	--	0.005	--	--	0.005	--	--	0.048								
39	0.006	--	--	0.007	--	--	0.006	--	--	0.058								
40	0.004	--	--	0.005	--	--	0.005	--	--	0.046								

Note:
Each phase output current ≤ 16A, it shall be complied with EN 61000-3-2.
The tests were performed on both EFWN511 and EFWN511B.

B.1 (a)		TABLE: Harmonic current								P								
Model: EFWN511B																		
Order no.	Ambient condition 50 °C									Current Limits (A)								
	Current Magnitude (A)																	
	Output 100%Pn			Output 66%Pn			Output 33%Pn											
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
1	--	--	--	--	--	--	--	--	--	--								
2	0.019	--	--	0.019	--	--	0.018	--	--	1.080								
3	0.081	--	--	0.063	--	--	0.043	--	--	2.300								
4	0.005	--	--	0.005	--	--	0.006	--	--	0.430								
5	0.043	--	--	0.029	--	--	0.014	--	--	1.140								
6	0.005	--	--	0.005	--	--	0.004	--	--	0.300								
7	0.021	--	--	0.007	--	--	0.008	--	--	0.770								
8	0.003	--	--	0.003	--	--	0.003	--	--	0.230								
9	0.008	--	--	0.007	--	--	0.008	--	--	0.400								
10	0.003	--	--	0.003	--	--	0.003	--	--	0.184								
11	0.005	--	--	0.004	--	--	0.009	--	--	0.330								
12	0.003	--	--	0.003	--	--	0.003	--	--	0.153								
13	0.006	--	--	0.007	--	--	0.008	--	--	0.210								
14	0.003	--	--	0.003	--	--	0.004	--	--	0.131								
15	0.007	--	--	0.008	--	--	0.007	--	--	0.150								
16	0.003	--	--	0.003	--	--	0.003	--	--	0.115								
17	0.007	--	--	0.007	--	--	0.006	--	--	0.132								
18	0.003	--	--	0.003	--	--	0.003	--	--	0.102								
19	0.005	--	--	0.006	--	--	0.005	--	--	0.118								
20	0.003	--	--	0.003	--	--	0.003	--	--	0.092								
21	0.008	--	--	0.006	--	--	0.006	--	--	0.107								
22	0.002	--	--	0.003	--	--	0.003	--	--	0.084								
23	0.006	--	--	0.005	--	--	0.006	--	--	0.098								
24	0.004	--	--	0.003	--	--	0.003	--	--	0.077								
25	0.004	--	--	0.005	--	--	0.006	--	--	0.090								
26	0.004	--	--	0.004	--	--	0.003	--	--	0.071								
27	0.004	--	--	0.005	--	--	0.006	--	--	0.083								
28	0.004	--	--	0.003	--	--	0.003	--	--	0.066								
29	0.005	--	--	0.006	--	--	0.006	--	--	0.078								
30	0.005	--	--	0.004	--	--	0.004	--	--	0.061								
31	0.007	--	--	0.005	--	--	0.006	--	--	0.073								
32	0.005	--	--	0.006	--	--	0.004	--	--	0.058								
33	0.005	--	--	0.006	--	--	0.006	--	--	0.068								
34	0.004	--	--	0.006	--	--	0.005	--	--	0.054								
35	0.006	--	--	0.006	--	--	0.007	--	--	0.064								
36	0.005	--	--	0.005	--	--	0.005	--	--	0.051								
37	0.006	--	--	0.007	--	--	0.007	--	--	0.061								
38	0.005	--	--	0.005	--	--	0.005	--	--	0.048								
39	0.006	--	--	0.006	--	--	0.007	--	--	0.058								
40	0.006	--	--	0.005	--	--	0.004	--	--	0.046								

Note:
 Each phase output current ≤ 16A, it shall be complied with EN 61000-3-2.
 The tests were performed on both EFWN511 and EFWN511B.

B.1 (c)		TABLE: Voltage fluctuation and flicker								P								
Model: EFWN511																		
Ambient condition 25 °C																		
Output	100%Pn			66%Pn			33%Pn			Limit								
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
P _{st}	0.172	--	--	0.173	--	--	0.171	--	--	≤ 1.0								
P _{lt}	0.167	--	--	0.169	--	--	0.166	--	--	≤ 0.65								
d(t) (ms)	0	--	--	0	--	--	0	--	--	500								
d _c (%)	0.324	--	--	0.325	--	--	0.316	--	--	≤ 3.3								
d _{max} (%)	0.573	--	--	0.583	--	--	0.604	--	--	≤ 4.0								
Ambient condition -10 °C																		
Output	100%Pn			66%Pn			33%Pn			Limit								
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
P _{st}	0.174	--	--	0.174	--	--	0.142	--	--	≤ 1.0								
P _{lt}	0.170	--	--	0.167	--	--	0.138	--	--	≤ 0.65								
d(t) (ms)	0	--	--	0	--	--	0	--	--	500								
d _c (%)	0.314	--	--	0.313	--	--	0.210	--	--	≤ 3.3								
d _{max} (%)	0.551	--	--	0.548	--	--	0.449	--	--	≤ 4.0								
Ambient condition 50 °C																		
Output	100%Pn			66%Pn			33%Pn			Limit								
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
P _{st}	0.170	--	--	0.168	--	--	0.167	--	--	≤ 1.0								
P _{lt}	0.165	--	--	0.164	--	--	0.162	--	--	≤ 0.65								
d(t) (ms)	0	--	--	0	--	--	0	--	--	500								
d _c (%)	0.315	--	--	0.318	--	--	0.306	--	--	≤ 3.3								
d _{max} (%)	0.590	--	--	0.571	--	--	0.500	--	--	≤ 4.0								
Model: EFWN511B																		
Ambient condition 25 °C																		
Output	100%Pn			66%Pn			33%Pn			Limit								
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
P _{st}	0.0287	--	--	0.0282	--	--	0.0234	--	--	≤ 1.0								
P _{lt}	0.0287	--	--	0.0282	--	--	0.0234	--	--	≤ 0.65								
d(t) (ms)	0	--	--	0	--	--	0	--	--	500								
d _c (%)	0.0365	--	--	0.0467	--	--	0.0598	--	--	≤ 3.3								
d _{max} (%)	0.5659	--	--	0.5489	--	--	0.5304	--	--	≤ 4.0								
Ambient condition -10 °C																		
Output	100%Pn			66%Pn			33%Pn			Limit								
	L1	L2	L3	L1	L2	L3	L1	L2	L3									
P _{st}	0.0287	--	--	0.0282	--	--	0.0234	--	--	≤ 1.0								
P _{lt}	0.0287	--	--	0.0282	--	--	0.0234	--	--	≤ 0.65								
d(t) (ms)	0	--	--	0	--	--	0	--	--	500								
d _c (%)	0.0567	--	--	0.0494	--	--	0.0449	--	--	≤ 3.3								
d _{max} (%)	0.5643	--	--	0.5343	--	--	0.5342	--	--	≤ 4.0								

Output	Ambient condition 50 °C									Limit	
	100%Pn			66%Pn			33%Pn				
	L1	L2	L3	L1	L2	L3	L1	L2	L3		
P _{st}	0.0287	--	--	0.0284	--	--	0.0244	--	--	≤ 1.0	
P _{lt}	0.0287	--	--	0.0284	--	--	0.0244	--	--	≤ 0.65	
d(t) (ms)	0	--	--	0	--	--	0	--	--	500	
d _c (%)	0.0617	--	--	0.0487	--	--	0.0252	--	--	≤ 3.3	
d _{max} (%)	0.5658	--	--	0.5548	--	--	0.5379	--	--	≤ 4.0	


Note:
 Each phase output current ≤ 16A, it shall be complied with EN 61000-3-3.
 The tests were performed on both EFWN511 and EFWN511B.



Screenshot of 100%Pn at 50 °C



Screenshot of 66%Pn at 50 °C




Screenshot of 33%Pn at 50 °C



B.1.1.1 & B.1.1.2	TABLE: Conditions of connection, reconnection and gradual power supply of active power		P			
Model: EFWN511						
Voltage conditions						
a) Out of voltage range	84% U_n for 30s	111% U_n for 30s				
Connection:	No connection	No connection				
Limit	No connection allowed					
b) In voltage range at start-up	85% U_n < U < 110% U_n					
Voltage limit	86% U_n	109% U_n				
Reconnection time [s]	326.0	326.1				
Limit:	> 30s					
Gradient:	8.03	7.89				
Limit:	20%Pn/min					
c) In voltage range after voltage failure	85% U_n < U < 110% U_n					
Voltage limit	86% U_n	109% U_n				
Reconnection time [s]	329.6	328.5				
Limit:	> 300s					
Gradient:	8.13	7.78				
Limit:	20%Pn/min					
Frequency conditions						
d) Out of frequency range	49.88 ± 0.01	50.12 ± 0.01				
Connection:	No connection	No connection				
Limit	No connection allowed					
e) In frequency range at start-up	49.90 Hz < f < 50.10 Hz					
Frequency limit [Hz]	49.91	50.09				
Reconnection time [s]	333.0	333.6				
Limit:	> 30s					
Gradient:	7.87	8.00				
Limit:	20%Pn/min					
f) In frequency range after frequency failure	49.90 Hz < f < 50.10 Hz					
Frequency limit [Hz]	49.91	50.09				
Reconnection time [s]	613.7	328.7				
Limit:	> 300s					
Gradient:	8.01	8.00				
Limit:	20%Pn/min					
Note:						
Test condition b) and c): voltage within the limits of 85% to 110%						
Test condition e) and f): frequency within the limits of 49.90Hz to 50.10Hz						
For gradient, it should be recorded for at least 300s until the inverter has the full output power.						
The tests were performed on EFWN511 and are also applicable for all other models stated in this report.						


Graph of the reconnection after under-voltage failure

Connection, reconnection and gradual power supply 85%Un




Graph of the reconnection after over-voltage failure

Connection, reconnection and gradual power supply 110%Un




Graph of the reconnection after under-frequency failure

Connection, reconnection and gradual power supply 49.9Hz



Graph of the reconnection after over-frequency failure

Connection, reconnection and gradual power supply 50.10Hz




B.1.2.2.2		TABLE: Inverter in systems with total capacity (greater than 11.08 kW)					P
Model	EFWN511						
Inductive supply reactive power Q = 48.43% Pn							
Test power P/Pn	Target Q/Pn	Measured P/Pn	Measured Q/Pn	Deviation Δ Q/Pn	Power factor cos φ	± 2.5%	
0% - 10%	48.43%	4.9%	47.8%	-0.6%	0.103		
10% - 20%	48.43%	14.9%	47.8%	-0.6%	0.298		
20% - 30%	48.43%	24.8%	47.7%	-0.7%	0.462		
30% - 40%	48.43%	34.8%	47.7%	-0.7%	0.589		
40% - 50%	48.43%	44.8%	47.7%	-0.7%	0.684		
50% - 60%	48.43%	54.7%	47.7%	-0.7%	0.754		
60% - 70%	48.43%	64.7%	47.7%	-0.7%	0.805		
70% - 80%	48.43%	74.6%	47.7%	-0.7%	0.843		
80% - 90%	48.43%	84.6%	47.7%	-0.7%	0.871		
90% - 100%	48.43%	86.6%*	47.7%	-0.7%	0.876		
Capacitive supply reactive power Q = - 48.43% Pn							
Test power P/Pn	Target Q/Pn	Measured P/Pn	Measured Q/Pn	Deviation Δ Q/Pn	Power factor cos φ	± 2.5%	
0% - 10%	48.43%	5.0%	-48.5%	-0.1%	0.103		
10% - 20%	48.43%	15.0%	-48.5%	-0.1%	0.295		
20% - 30%	- 48.43%	25.0%	-48.5%	-0.1%	0.457		
30% - 40%	- 48.43%	34.9%	-48.5%	-0.1%	0.584		
40% - 50%	- 48.43%	44.9%	-48.5%	-0.1%	0.679		
50% - 60%	- 48.43%	54.8%	-48.5%	-0.1%	0.749		
60% - 70%	- 48.43%	64.8%	-48.4%	0.0%	0.800		
70% - 80%	- 48.43%	74.7%	-48.5%	-0.1%	0.838		
80% - 90%	- 48.43%	84.7%	-48.5%	-0.1%	0.867		
90% - 100%	- 48.43%	87.9%*	-48.5%	-0.1%	0.875		
No reactive power supply cos φ = 1							
Test power P/Pn	Target Q/Pn	Measured P/Pn	Measured Q/Pn	Deviation Δ Q/Pn	Power factor cos φ	± 2.5%	
0% - 10%	0	5.0%	+0.6%	+0.6%	0.943		
10% - 20%	0	15.0%	+0.6%	+0.6%	0.993		
20% - 30%	0	25.0%	+0.6%	+0.6%	0.997		
30% - 40%	0	35.0%	+0.6%	+0.6%	0.998		
40% - 50%	0	45.0%	+0.6%	+0.6%	0.998		
50% - 60%	0	55.0%	+0.6%	+0.6%	0.999		
60% - 70%	0	65.0%	+0.6%	+0.6%	0.999		
70% - 80%	0	75.0%	+0.6%	+0.6%	0.999		
80% - 90%	0	85.0%	+0.6%	+0.6%	0.999		
90% - 100%	0	94.9%	+0.6%	+0.6%	0.999		


Note:

When operating above the apparent power threshold S_{min} equal to 10 % of the maximum apparent power S_{max} or the minimum regulating level of the generating plant, whichever is the higher value, the reactive power capability shall be provided with an accuracy of $\pm 2\% S_{max}$. Up to this apparent power threshold S_{min} , deviations above 2 % are permissible.

* The inverter can't output the desired active power due to current limitation, so don't consider the deviation value.

The tests were performed on EFWN511 and are also applicable for all other models stated in this report.



B.1.2.3.1	TABLE: Procedures for performing tests and recording results (hypothesis of adjustment by Q) (greater than 11.08 kW)			N/A			
Model: EFWN511							
	Reactive power set point Q/Pn [%]	Measured reactive power Q/Pn [%]	Deviation compared to set-point $\Delta Q/Pn$ [%]				
- Q _{min}	-48.43						
0	0						
+ Q _{max}	+48.43						
Limit		$\Delta Q \leq \pm 2,5\% P_n$					
Test:							
DC source should be set to 50% output power Starting with $Q_{min} \leq -0,4843 P_n$ to $Q=0$ and then to $Q_{max} \geq 0,4843 P_n$, in doing so each point must be kept for at least 3 minute.							
The total tolerance is $\Delta Q \leq \pm 2,5\% \text{ of } P_n$ or $\Delta \cos\varphi \leq \pm 0.01$							
The tests covered by this paragraph are only mandatory for inverters used in systems with power greater than 11.08 kW, but at the request of the manufacturer they can be carried out and documented even for smaller converters.							
							

B.1.2.4	TABLE: Response time to an assigned step level change (greater 11.08 kW)	N/A
---------	---	-----

Model: EFWN511**Test result : 50% P_n**

	Reactive power set point $Q/P_n [\%]$	Measured reactive power $Q/P_n [\%]$	Deviation compared to setpoint $\Delta Q/P_n [\%]$
0	0		
$-Q_{\min}$	-48.43		
$+Q_{\max}$	+48.43		
0	0		
Response time [s]	$Q=0$ to $-Q_{\min}$	$-Q_{\min}$ to $+Q_{\max}$	$+Q_{\max}$ to $Q=0$
	1.2	1.8	1.0

Test result : 100% P_n

	Reactive power set point $Q/P_n [\%]$	Measured reactive power $Q/P_n [\%]$	Deviation compared to setpoint $\Delta Q/P_n [\%]$
0	0		
$-Q_{\min}$	-48.43		
$+Q_{\max}$	+48.43		
0	0		
Response time [s]	$Q=0$ to $-Q_{\min}$	$-Q_{\min}$ to $+Q_{\max}$	$+Q_{\max}$ to $Q=0$
	1.2	1.8	1.0
Limit	$\Delta Q \leq \pm 5\%$ of P_n Max response time 10s		


Test:


DC source should be set to 50%(test1) and 100%(test2) output power

Starting with $Q=0$ then $Q_{\min} \leq -0,4843 P_n$ to $Q_{\max} \geq 0,4843 P_n$, and then back to $Q=0$ in doing so each point must be kept for at least 2 minute.The total tolerance is $\Delta Q \leq \pm 5,0\%$ of P_n or $\Delta \cos \varphi \leq \pm 0,01$

The maximum response time is 10s.

As for the requirements of the previous paragraph, also in this case the tests are required to inverters used in plants with a total power greater than 11.08 kW, which must also be able to implement a centralized control strategy via remote control signal, issued by the Distributor. However, the manufacturer has the right to voluntarily carry out tests even for smaller inverters.



B.1.2.5.1		TABLE: Verification of compliance with the methods of application of the standard characteristic curve, $\cos\phi = f(P)$						P																																																																														
Model: EFWN511																																																																																						
$\cos\phi = f(P)$																																																																																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Condition P/Pn</th><th>Condition U/Un</th><th>Target cosφ</th><th>Measured P/Pn</th><th>Measured Q/Pn</th><th>Measured cosφ</th><th>Deviation Δ cosφ</th><th>Limit Δ cosφ</th></tr> </thead> <tbody> <tr> <td>20%</td><td>104%</td><td>1.000</td><td>20.1%</td><td>0.2%</td><td>0.995</td><td>-0.005</td><td rowspan="12" style="vertical-align: middle; text-align: center;">± 0.01</td></tr> <tr> <td>30%</td><td>104%</td><td>1.000</td><td>30.2%</td><td>0.2%</td><td>0.997</td><td>-0.003</td></tr> <tr> <td>40%</td><td>104%</td><td>1.000</td><td>40.2%</td><td>0.2%</td><td>0.998</td><td>-0.002</td></tr> <tr> <td>50%</td><td>104%</td><td>1.000</td><td>50.3%</td><td>0.2%</td><td>0.998</td><td>-0.002</td></tr> <tr> <td>60%</td><td>104%</td><td>1.000</td><td>60.4%</td><td>0.2%</td><td>0.999</td><td>-0.001</td></tr> <tr> <td>60%</td><td>106%</td><td>0.980</td><td>60.4%</td><td>-12.1%</td><td>0.979</td><td>-0.001</td></tr> <tr> <td>70%</td><td>106%</td><td>0.960</td><td>70.7%</td><td>-20.4%</td><td>0.959</td><td>-0.001</td></tr> <tr> <td>80%</td><td>106%</td><td>0.940</td><td>80.6%</td><td>-29.1%</td><td>0.939</td><td>-0.001</td></tr> <tr> <td>90%</td><td>106%</td><td>0.920</td><td>90.7%</td><td>-38.5%</td><td>0.920</td><td>0</td></tr> <tr> <td>100%</td><td>106%</td><td>0.900</td><td>90.7%*</td><td>-38.5%</td><td>0.920</td><td>--</td></tr> </tbody> </table>								Condition P/Pn	Condition U/Un	Target cosφ	Measured P/Pn	Measured Q/Pn	Measured cosφ	Deviation Δ cosφ	Limit Δ cosφ	20%	104%	1.000	20.1%	0.2%	0.995	-0.005	± 0.01	30%	104%	1.000	30.2%	0.2%	0.997	-0.003	40%	104%	1.000	40.2%	0.2%	0.998	-0.002	50%	104%	1.000	50.3%	0.2%	0.998	-0.002	60%	104%	1.000	60.4%	0.2%	0.999	-0.001	60%	106%	0.980	60.4%	-12.1%	0.979	-0.001	70%	106%	0.960	70.7%	-20.4%	0.959	-0.001	80%	106%	0.940	80.6%	-29.1%	0.939	-0.001	90%	106%	0.920	90.7%	-38.5%	0.920	0	100%	106%	0.900	90.7%*	-38.5%	0.920	--
Condition P/Pn	Condition U/Un	Target cosφ	Measured P/Pn	Measured Q/Pn	Measured cosφ	Deviation Δ cosφ	Limit Δ cosφ																																																																															
20%	104%	1.000	20.1%	0.2%	0.995	-0.005	± 0.01																																																																															
30%	104%	1.000	30.2%	0.2%	0.997	-0.003																																																																																
40%	104%	1.000	40.2%	0.2%	0.998	-0.002																																																																																
50%	104%	1.000	50.3%	0.2%	0.998	-0.002																																																																																
60%	104%	1.000	60.4%	0.2%	0.999	-0.001																																																																																
60%	106%	0.980	60.4%	-12.1%	0.979	-0.001																																																																																
70%	106%	0.960	70.7%	-20.4%	0.959	-0.001																																																																																
80%	106%	0.940	80.6%	-29.1%	0.939	-0.001																																																																																
90%	106%	0.920	90.7%	-38.5%	0.920	0																																																																																
100%	106%	0.900	90.7%*	-38.5%	0.920	--																																																																																
<p>Note: The lock-in value is adjustable between V_n and $1.1V_n$ and the lock-out value between V_n and $0.9V_n$ in 0.01V steps. * The inverter can't output the desired active power due to current limitation, so don't consider the deviation value. The tests were performed on EFWN511 and are also applicable for all other models stated in this report.</p>																																																																																						
<p style="text-align: center;">Graph of $\cos\phi = f(P)$</p>  <p>The graph plots cosφ against the power ratio P/Pn. The x-axis ranges from 20% to 100% in 10% increments. The y-axis ranges from 0.85 to 1.03 in 0.02 increments. A solid yellow line with circular markers represents the measured cosφ, which remains constant at approximately 0.992 for P/Pn < 60%, then drops sharply to about 0.895 at 100%. A dashed blue line with circular markers represents the lower tolerance limit, which is constant at approximately 0.992 for P/Pn < 60%, then jumps to 1.000 at 60% and stays constant. A dashed grey line with circular markers represents the upper tolerance limit, which is constant at approximately 1.010 for P/Pn < 60%, then drops sharply to about 0.910 at 100%. A solid blue line with circular markers represents the U/Un ratio, which is constant at approximately 0.985 for P/Pn < 60%, then jumps to 1.000 at 60% and stays constant.</p>																																																																																						

B.1.2.6.1	TABLE: Verification of compliance with the methods of application of the standard characteristic curve, $Q = f(V)$ (greater than 11.08 kW)					N/A					
Model: EFWN511											
Q_{\min} reactive power in accordance to standard characteristic curve $Q = f(V)$											
Condition P/Pn	Condition U/Un	Target Q	Measured P/Pn	Measured U/Un	Measured Q/Pn	$\Delta Q/Pn$ [$\leq \pm 2.5\%$]					
< 20%	1.07	$\approx 0 (< \pm 2.5\% Pn)$									
< 20%	1.09	$\approx 0 (< \pm 2.5\% Pn)$									
< 20%->30%	1.09	-0.5 Q_{\min} (within 10s)									
40%	1.09	-0.5 Q_{\min}									
50%	1.09	-0.5 Q_{\min}									
60%	1.09	-0.5 Q_{\min}									
70%	1.09	-0.5 Q_{\min}									
80%	1.09	-0.5 Q_{\min}									
90%	1.09	-0.5 Q_{\min}									
100%	1.09	-0.5 Q_{\min}									
100%	1.10	- Q_{\min}									
100%->10%	1.10	- Q_{\min}									
10%- ≤5%	1.10	$\approx 0 (< \pm 2.5\% Pn)$									
Q_{\max} reactive power in accordance to standard characteristic curve $Q = f(V)$											
Condition P/Pn	Condition U/Un	Target Q	Measured P/Pn	Measured U/Un	Measured Q/Pn	$\Delta Q/Pn$ [$\leq \pm 2.5\%$]					
< 20%	0.93	$\approx 0 (< \pm 2.5\% Pn)$									
< 20%	0.91	$\approx 0 (< \pm 2.5\% Pn)$									
< 20%->30%	0.91	-0.5 Q_{\max} (within 10s)									
40%	0.91	-0.5 Q_{\max}									
50%	0.91	-0.5 Q_{\max}									
60%	0.91	-0.5 Q_{\max}									
70%	0.91	-0.5 Q_{\max}									
80%	0.91	-0.5 Q_{\max}									
90%	0.91	-0.5 Q_{\max}									
100%	0.91	-0.5 Q_{\max}									
100%	0.90	- Q_{\max}									
100%->10%	0.90	- Q_{\max}									
10%- ≤5%	0.90	$\approx 0 (< \pm 2.5\% Pn)$									


Note:


The lock-in value is adjustable between V_n and $1.1V_n$ and the lock-out value between V_n and $0.9V_n$ in $0.01V$ steps.

The inverter voltage on the AC side of the (inverter) is rated to 380V line to line.

In reference to the circular characteristic, the inverter reduces the active output power to maintain the reactive output power.

The under-voltage measurement effects the active output power in reference to reactive output power since the reactive output power has always priority. Therefore inverter must lower the active output power.




B.1.3.1	TABLE: Automatic limitation of the active power for voltage values close to 110% of the rated voltage P(U)				P				
Model: EFWN511									
Test sequence for the static behavior (Threshold set: 110% Un)									
Test voltage U/Un	Target P/Pn	Measured U/Un	Measured P/Pn	Deviation ΔP / Pn	Limitation				
100	100%	100.2%	100.0%	0%	± 10%				
108	100%	108.2%	99.8%	-0.2%					
112	20%	112.1%	17.6%	-2.4%					
108	100%	108.2%	99.8%	-0.2%					
Reduced time measurement									
From 100%Pn to 20%Pn			3.1 min		≤ 5 min				
Notes: The tests were performed on EFWN511 and are also applicable for all other models stated in this report.									
Graph of static behavior									
 <p>The graph illustrates the static behavior of the EFWN511 model. The x-axis represents Time in seconds (s), ranging from 0 to 1200. The left y-axis represents Power as a percentage of rated power (P/Pn), ranging from 0% to 120%. The right y-axis represents Voltage as a percentage of rated voltage (U/Un), ranging from 80% to 115%. The blue line (P/Pn) starts at 100%, drops to 20% at approximately 450s, and then rises sharply to 100% at approximately 1098s. The orange line (U/Un) starts at 100%, drops to 20% at approximately 450s, and then rises to 110% at approximately 1098s. Two data points are highlighted: (912.2, 18%) on the P/Pn curve and (1098.4, 99%) on the U/Un curve.</p>									

B.1.3.2		TABLE: Adjusting active power in the presence of transients on the transmission network						P						
Model: EFWN511														
Measurement sequence A														
Power output:		100% P _n												
Starting frequency f ₁ :		50.2 Hz												
Deactivation threshold f _{stop} :		50.0 Hz (Activated)												
Droop:		2.6% (76.9% P _{ref} / Hz), P _{ref} = P _{max}												
Test condition		Measurement						Limit ΔP/P _n ± 2.5%						
f (Hz)	Target P/P _n	f (Hz)	P/P _n	T _{sr_95%} (s)	T _{settling} (s)	T _d (s)	ΔP/P _n							
a) 47.51	100%	47.51	98.90%	--	--	--	-1.10%							
b) 50.15	98%	50.15	98.79%	--	--	--	-1.21%							
c) 50.40	84.6%	50.40	84.51%	--	--	--	-0.09%							
d) 50.60	69.2%	50.60	69.64%	--	--	--	0.44%							
e) 51.49	0.8%	51.49	0.02%	--	--	--	-0.78%							
f) 50.11	0.8%	50.11	0.02%	--	--	--	-0.78%							
g) 50.00	0.8%	50.00	0.02%	--	--	--	-0.78%							
h) 50.00	100%	50.00	98.85%	--	849.6	--	-1.15%							
Test condition		Measurement						Limit						
g) 50.00 to h) 50.00		Max. power gradient (%P _n /min):			6.78		≤20% P _n /min							
Measurement sequence B														
Power output:		50% P _n												
Starting frequency f ₁ :		50.2 Hz												
Deactivation threshold f _{stop} :		50.0 Hz (Activated)												
Droop:		5.2% (38.4% P _{ref} / Hz), P _{ref} = P _{max}												
Test condition		Measurement						Limit ΔP/P _n ± 2.5%						
f (Hz)	Target P/P _n	f (Hz)	P/P _n	T _{sr_95%} (s)	T _{settling} (s)	T _d (s)	ΔP/P _n							
a) 47.51	50%	47.51	49.60%	--	--	--	-0.40%							
b) 50.15	98%	50.15	49.53%	--	--	--	-0.47%							
c) 50.40	42.3%	50.40	42.22%	--	--	--	-0.08%							
d) 50.60	34.6%	50.60	34.80%	--	--	--	0.20%							
e) 51.49	0.4%	51.49	0.02%	--	--	--	-0.38%							
f) 50.11	0.4%	50.11	0.02%	--	--	--	-0.38%							
g) 50.00	0.4%	50.00	0.02%	--	--	--	-0.38%							
h) 50.00	50%	50.00	49.48%	--	388.2	--	-0.52%							
Test condition		Measurement						Limit						
g) 50.00 to h) 50.00		Max. power gradient (%P _n /min):			6.97		≤20% P _n /min							
Note: The tests were performed on EFWN511 and are also applicable for all other models stated in this report.														


Graph of sequence A

100% Pn



Graph of sequence B


50% Pn




B.1.3.3.1	TABLE: Reduction of active power in the presence of under-frequency transients on transmission network				P
Model: EFWN511					
Output voltage	230 Vac				
Test sequence	Frequency [Hz]	Measured output P/Pn	$\Delta P/Pn$ per 1 Hz	Reduction rate of stringent limits	
Test a)	50.0	100.0%	0%	0	
Test b)	49.5	100.1%	0.1%	0	
Test c)	49.0	100.0%	0%	0	
Test d)	48.5	100.0%	0%	-1%	
Test e)	48.5	100.0%	0%	-2%	
Test f)	47.5	100.0%	0%	-3%	

Note:

Graph of frequency and power from step 50.0Hz to 47.5Hz



B.1.3.4	TABLE: Limitation of active power by external control from the distributor			P	
Model: EFWN511					
Target P/Pn	Measured output P/Pn	Accuracy ΔP/Pn	Limit ΔP/Pn		
100%	99.1%	-0.9%	± 2.5%		
90%	89.1%	-0.9%			
80%	79.1%	-0.9%			
70%	69.2%	-0.8%			
60%	59.2%	-0.8%			
50%	49.2%	-0.8%			
40%	39.2%	-0.8%			
30%	29.2%	-0.8%			
20%	19.2%	-0.8%			
10%	9.2%	-0.8%			
0%	0.3%	0.3%			
Note:					
Graph of power from 100% Pn to 0%					
 <p>The graph illustrates the power limitation process. It begins at 100% Pn at 0 seconds. Between 0 and 900 seconds, the power remains constant at 100%. From 900 to 1500 seconds, it drops to approximately 88% Pn. Between 1500 and 2200 seconds, it drops to approximately 78% Pn. Between 2200 and 2800 seconds, it drops to approximately 68% Pn. Between 2800 and 3400 seconds, it drops to approximately 58% Pn. Between 3400 and 4000 seconds, it drops to approximately 48% Pn. Between 4000 and 4600 seconds, it drops to approximately 38% Pn. Between 4600 and 5200 seconds, it drops to approximately 28% Pn. Between 5200 and 5800 seconds, it drops to approximately 18% Pn. Finally, between 5800 and 6400 seconds, it drops to approximately 8% Pn, and then to 0% Pn by approximately 6800 seconds.</p>					

B.1.4.1 TABLE: Verification of the emission of continuous component			N/A
Model: EFWN511			
Phase A			
Power Level	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient condition 25 °C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Ambient condition -10 °C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Ambient condition 50°C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Phase B			
Power Level	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient condition 25 °C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Ambient condition -10 °C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			

Ambient condition 50°C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Phase C			
Power Level	(33 ± 5)%	(66 ± 5)%	(100 ± 5)%
Ambient condition 25 °C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Ambient condition -10 °C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Ambient condition 50°C			
Power (W)			
Voltage (V)			
Current (A)			
PF			
Cosφ			
DC Component (A)			
DC Component (% In)			
Note: Isolated Equipment			

Graph of power 100%/66%/33% at 25 °C
Graph of power 100%/66%/33% at -10 °C
Graph of power 100%/66%/33% at 50 °C

B.1.4.2	TABLE: Verification of the protections against the induction of a continuous component				N/A
Model: EFWN511					
Actual Power	Limits	Measurement: (mA)	Limiting value: (mA)	Disconnection time: (ms)	
$I_{dc} = 0,5\% \text{ of } I_{nom}$					
100%	+0.5% I_{nom} /1s		181		
66%	+0.5% I_{nom} /1s		181		
33%	+0.5% I_{nom} /1s		181		
100%	-0.5% I_{nom} /1s		181		
66%	-0.5% I_{nom} /1s		181		
33%	-0.5% I_{nom} /1s		181		
$I_{dc} = 1A$					
100%	+1A $I_{dc}/200ms$		1000		
66%	+1A $I_{dc}/200ms$		1000		
33%	+1A $I_{dc}/200ms$		1000		
100%	-1A $I_{dc}/200ms$		1000		
66%	-1A $I_{dc}/200ms$		1000		
33%	-1A $I_{dc}/200ms$		1000		
Note: Isolated Equipment					

Screenshot of power 100% at +0.5% I_{nom}
Screenshot of power 100% at -0.5% I_{nom}
Screenshot of power 100% at +1A I_{dc}
Screenshot of power 100% at -1A I_{dc}

B.1.5	TABLE: Verification of insensitivity to voltage dips (UVRT capability, greater than 11.08 kW)	N/A
-------	--	-----

Model: EFWN511

Requirement of LVRT test:

Table 24 - Test sequences to verify immunity to temporary voltage dips. The amplitude, duration and shape relate to no-load test conditions

List of tests	Residual amplitude of phase-to-phase voltage V/V_{nom}	Drop duration limit [ms]	Power re-supply time after restoring network [ms]	Form (*)
1s – three-phase symmetrical fault	$0.10 \pm 0.05 (V_1/V_n)$	200 ± 20	400	
1a – two-phase asymmetric failure	$0.10 \pm 0.05 (V_1/V_n)$	200 ± 20	400	
2s – three-phase symmetrical fault	$0.25 \pm 0.05 (V_2/V_n)$	400 ± 20	400	
2a – two-phase asymmetric failure	$0.25 \pm 0.05 (V_2/V_n)$	400 ± 20	400	
3s – three-phase asymmetrical fault	$0.50 \pm 0.05 (V_3/V_n)$	850 ± 20	400	
3a – two-phase asymmetric failure	$0.50 \pm 0.05 (V_3/V_n)$	850 ± 20	400	
4s – three-phase asymmetrical fault	$0.75 \pm 0.05 (V_4/V_n)$	1300 ± 20	400	
4a – two-phase asymmetric failure	$0.75 \pm 0.05 (V_4/V_n)$	1300 ± 20	400	
5 – LV two-phase asymmetric fault	$0.10 \pm 0.05 (V_5/V_n)$	200 ± 20	400	
6 – LV two-phase asymmetric fault	$0.50 \pm 0.05 (V_6/V_n)$	850 ± 20	400	

Test No.	V/V_{nom}	Phase-to-earth voltages			Phase angles		
		$U_1/U_{1,\text{nom}}$	$U_2/U_{2,\text{nom}}$	$U_3/U_{3,\text{nom}}$	φ_{U1}	φ_{U2}	φ_{U3}
1s	0.10 ± 0.05	0.10 ± 0.05	0.10 ± 0.05	0.10 ± 0.05	0°	-120°	120°
1a	0.10 ± 0.05	0.87 ± 0.05	0.87 ± 0.05	0.10 ± 0.05	27°	-147°	120°
2s	0.25 ± 0.05	0.25 ± 0.05	0.25 ± 0.05	0.25 ± 0.05	0°	-120°	120°
2a	0.25 ± 0.05	0.88 ± 0.05	0.88 ± 0.05	0.25 ± 0.05	22°	-142°	120°
3s	0.50 ± 0.05	0.50 ± 0.05	0.50 ± 0.05	0.50 ± 0.05	0°	-120°	120°
3a	0.50 ± 0.05	0.90 ± 0.05	0.90 ± 0.05	0.50 ± 0.05	14°	-134°	120°
4s	0.75 ± 0.05	0.75 ± 0.05	0.75 ± 0.05	0.75 ± 0.05	0°	-120°	120°
4a	0.75 ± 0.05	0.94 ± 0.05	0.94 ± 0.05	0.75 ± 0.05	7°	-127°	120°
5	0.10 ± 0.05	1	0.10 ± 0.05	0.10 ± 0.05	0°	-120°	120°
6	0.50 ± 0.05	1	0.50 ± 0.05	0.50 ± 0.05	0°	-120°	120°
normal condition	1	1	1	1	0°	-120°	120°

Graph of LVRT test:

List of tests	Residual amplitude of phase-to-phase voltage V/V _{nom}	Drop duration limit [ms]	Measured drop duration [ms]	Duration of restoring network [ms]
1s – three-phase symmetrical fault (P = 0.1 – 0.3)	0.10 ± 0.05 (V ₁ /V _n)	200 +20		
1s – three-phase symmetrical fault (P > 0.9)	0.10 ± 0.05 (V ₁ /V _n)	200 +20		
1a – two-phase asymmetrical fault (P = 0.1 – 0.3)	0.10 ± 0.05 (V ₁ /V _n)	200 +20		
1a – two-phase asymmetrical fault (P > 0.9)	0.10 ± 0.05 (V ₁ /V _n)	200 +20		
2s – three-phase symmetrical fault (P = 0.1 – 0.3)	0.25 ± 0.05 (V ₂ /V _n)	400 +20		
2s – three-phase symmetrical fault (P > 0.9)	0.25 ± 0.05 (V ₂ /V _n)	400 +20		
2a – three-phase symmetrical fault (P = 0.1 – 0.3)	0.25 ± 0.05 (V ₂ /V _n)	400 +20		
2a – three-phase symmetrical fault (P > 0.9)	0.25 ± 0.05 (V ₂ /V _n)	400 +20		
3s – three-phase symmetrical fault (P = 0.1 – 0.3)	0.50 ± 0.05 (V ₃ /V _n)	850 ± 20		
3s – three-phase symmetrical fault (P > 0.9)	0.50 ± 0.05 (V ₃ /V _n)	850 ± 20		
3a – two-phase asymmetrical fault (P = 0.1 – 0.3)	0.50 ± 0.05 (V ₃ /V _n)	850 ± 20		
3a – two-phase asymmetrical fault (P > 0.9)	0.50 ± 0.05 (V ₃ /V _n)	850 ± 20		
4s – three-phase symmetrical fault (P = 0.1 – 0.3)	0.75 ± 0.05 (V ₄ /V _n)	1300 ± 20		
4s – three-phase symmetrical fault (P > 0.9)	0.75 ± 0.05 (V ₄ /V _n)	1300 ± 20		
4a – two-phase asymmetrical fault (P = 0.1 – 0.3)	0.75 ± 0.05 (V ₄ /V _n)	1300 ± 20		
4a – two-phase asymmetrical fault (P > 0.9)	0.75 ± 0.05 (V ₄ /V _n)	1300 ± 20		
5 – LV two-phase asymmetrical fault (P = 0.1 – 0.3)	0.10 ± 0.05 (V ₅ /V _n)	200 +20		
5 – LV two-phase asymmetrical fault (P > 0.9)	0.10 ± 0.05 (V ₅ /V _n)	200 +20		
6 – LV two-phase asymmetrical fault (P = 0.1 – 0.3)	0.50 ± 0.05 (V ₆ /V _n)	850+20		
6 – LV two-phase asymmetrical fault (P > 0.9)	0.50 ± 0.05 (V ₆ /V _n)	850 +20		


Note:


(*) Regardless of the method used to simulate transients (simulator or impedance network), the rise and fall time of the voltage must be less than 10 ms

The interface protection shall be disabled or adjusted to avoid spurious tripping during testing.

The test conditions are performed as worst-case conditions. The inverter feeds maximal active and reactive power during the complete test.

B.1.6.1	TABLE: Verification of insensitivity to automatic reclosing in phase discrepancy (simulation network)					P					
Model: EFWN511											
Test 1 - phase shift angle of 90°											
Power	Phase shift angle	Current 20 ms before phase shift		Current 200ms after phase shift		Result					
100% Pn	90°	Phase A	3.84 A	Phase A	3.56 A	Normal situation					
		Phase B	--	Phase B	--	Normal situation					
		Phase C	--	Phase C	--	Normal situation					
		Phase A/B/C	--	Phase A/B/C	--	Normal situation					
Test 2 - phase shift angle of 180°											
Power	Phase shift angle	Current 20 ms before phase shift		Current 200ms after phase shift		Result					
100% Pn	180°	Phase A	3.85 A	Phase A	3.56 A	Normal situation					
		Phase B	--	Phase B	--	Normal situation					
		Phase C	--	Phase C	--	Normal situation					
		Phase A/B/C	--	Phase A/B/C	--	Normal situation					
Note: The tests were performed on EFWN511 and are also applicable for all other models stated in this report.											





Appendix 1: ISO 9001 certificate

Certificate CN17/30219

The management system of

Dongguan Streamax Electronics Co., Ltd.

Unified Social Credit Code: 91441900MA560UJB4C

Business Registration Address: Room 101, No.20 Building, Leaguer Zijing Intelligent Manufacture Center, NO.105,

Qingbin East Road, Qingxi Town, Dongguan City, Guangdong Province, P. R. China

Business Operation Address: No.20 Building Leaguer Zijing Intelligent Manufacture Center, NO.105 Qingbin East Road, Qingxi Town, Dongguan City, Guangdong Province, P.R.China

has been assessed and certified as meeting the requirements of
ISO 9001:2015

For the following activities

Design and manufacture of cameras and DVR (digital video recorder) for electronic security equipment;

Design and manufacture of vehicle video terminals and satellite positioning system terminals;

Design and system integration of vehicle satellite positioning system terminals and video monitoring systems;

Manufacture of inverter



This certificate is valid from 13 April 2023 until 10 September 2024 and remains valid subject to satisfactory surveillance audits.
Issue 7. Certified since 03 January 2017

Certified activities performed by additional sites are listed on subsequent pages.

Jonathan M. Hall

Authorised by
Jonathan Hall
Global Head - Certification Services

SGS United Kingdom Ltd
Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN, UK
t +44 (0)151 350-6666 - www.sgs.com


The certification information can be verified on the web site of Certification and Accreditation Administration of the People's Republic of China
www.cnca.gov.cn



This document is an authentic electronic certificate for Client' business purposes use only. Printed version of the electronic certificate are permitted and will be considered as a copy. This document is issued by the Company subject to SGS General Conditions of certification services available on [Terms and Conditions | SGS](#). Attention is drawn to the limitation of liability, indemnification and jurisdictional clauses contained therein. This document is copyright protected and any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful.



Appendix 2: Datasheet of the relay



» Features

- High rating miniature PCB Relay.
- AC & DC coil are both available.
- UL/CUL and VDE approved.
- 17A 277VAC SPDT.
- Low profile 15.7mm and high insulation system class F.
- High CTI 250 material & New Glow Wire Approved.
(E version)
- Special version for inrush rating application is available.
(507 IR type)
- Complies with RoHS-Directive 2011/65/EU.
- Optional for halogen free version.

» Type List

◆ Standard type

Terminal style	Contact form	Insulation system	Designation (provided with)		
			Flux tight	Sealed type	Sealed type washable
PCB terminal	1A (SPNO)	F	507-1AH-F-C	507-1AH-F-V	507-1AH-F-S
	1C (SPDT)	F	507-1CH-F-C	507-1CH-F-V	507-1CH-F-S

◆ High sensitivity type (N) / Ultra-sensitivity type (N1)

PCB terminal	1A (SPNO)	F	507N-1AH-F-C	507N-1AH-F-V	507N-1AH-F-S
			507N1-1AH-F-C	507N1-1AH-F-V	507N1-1AH-F-S
	1C (SPDT)	F	507N-1CH-F-C	507N-1CH-F-V	507N-1CH-F-S
			507N1-1CH-F-C	507N1-1CH-F-V	507N1-1CH-F-S

◆ High power type

PCB terminal	1A (SPNO)	F	507H-1AH-F-C	507H-1AH-F-V	507H-1AH-F-S
	1C (SPDT)	F	507H-1CH-F-C	507H-1CH-F-V	507H-1CH-F-S

◆ High power type / High sensitivity type (N)

PCB terminal	1A (SPNO)	F	507HN-1AH-F-C	507HN-1AH-F-V	507HN-1AH-F-S
	1C (SPDT)	F	507HN-1CH-F-C	507HN-1CH-F-V	507HN-1CH-F-S

Note : 507A Special footprint 5.0mm pinning version can be selected.

» Ordering Information

507 - 1A H - - C
 1 2 3 4 5 6 7 8 9

- | | | | |
|----------|--|----------|------------------------------|
| 1. 507 | -- Basic series designation | 4. 1A | -- Single pole normally open |
| 2. Blank | -- Standard type
(1P - Terminal pitch 3.5mm)
(2P - Terminal pitch 5.0mm) | 1C | -- Single pole double throw |
| A | -- Standard type and special terminal pitch
(1P - Terminal pitch 5.0mm) | 2A | -- Double pole normally open |
| H | -- High power type (only for 1P type) | 2C | -- Double pole double throw |
| 3. Blank | -- Standard type(DC: 0.53 W) (AC: 0.75 VA) | 5. C | -- Contact material AgNi |
| N | -- High sensitivity type (0.40 W) | CA | -- Contact material AgNi+Au |
| N1 | -- Ultra-sensitivity type (0.25 W)(only for 1P type) | H | -- Contact material AgSnO |
| | | HA | -- Contact material AgSnO+Au |
| | | 6. Blank | -- Standard type |
| | | F | -- Class F |



7. C	-- Flux tight	E	-- CTI 250V
V	-- Sealed type	IR	-- 507 Inrush type(only for H, 1A/1C type)
S	-- Sealed type washable		
8. Blank	-- Standard type	9. <input checked="" type="checkbox"/>	-- Coil voltage (please refer to the coil rating data for the availability)

» Contact Rating

Type	1P			2P
	507、507N	507N1	507H、507HN	507、507N
Rated load (resistive)	12A 240VAC	10A 240VAC	16A 240VAC	8A 240VAC
Max. switching current	12A	10A	17A	8A
Max. switching voltage	277VAC	277VAC	277VAC	277VAC
Max. switching capacity	2880VA	2400VA	4080VA	1920VA

◆ Inrush type

Tungsten Lamp	NO:1500W 240VAC 30,000 ops. (Inrush 110A)
Halogen Lamp	NO:1500W 240VAC 30,000 ops. (Inrush 110A)


» Coil Rating (DC)

◆ Standard Type

Rated voltage (V)	Rated current ±10% at 23°C (mA)	Coil resistance ±10% at 23°C (Ω)	Max. continuous voltage at 85°C	Pick up voltage(Max.) at 23°C	Drop out voltage(Min.) at 23°C	Power consumption at rated voltage
3	176	17				
5	106	47				
6	88	68				
9	59	153				
12	44	272				
15	35	425				
18	29	611				
24	22	1,087				
36	15	2,445				
48	11	4,347				

◆ High sensitivity type (N)

Rated voltage (V)	Rated current ±10% at 23°C (mA)	Coil resistance ±10% at 23°C (Ω)	Max. continuous voltage at 85°C	Pick up voltage(Max.) at 23°C	Drop out voltage(Min.) at 23°C	Power consumption at rated voltage
3	133	22.5				
5	80	62				
6	67	90				
9	44	203				
12	33	360				
18	23	771				
24	17	1,440				
36	11	3,240				
48	9	5,520				



◆ Ultra-sensitivity type (N1)

Rated voltage (V)	Rated current ±10% at 23°C (mA)	Coil resistance ±10% at 23°C (Ω)	Max. continuous voltage at 85°C	Pick up voltage(Max.) at 23°C	Drop out voltage(Min.) at 23°C	Power consumption at rated voltage
3	83	36				
5	50	100				
6	42	144				
9	28	324	150 % of rated voltage	75 % of rated voltage	10 % of rated voltage	approx. 0.25W
12	21	576				
18	14	1,296				
24	10	2,304				
36	7	5,184				

»» Coil Rating (AC) [only for 507、507H]

Rated voltage (V)	Rated current ±10% at 23°C (mA)	Coil resistance ±10% at 23°C (Ω)	Max. continuous voltage at 70°C	Pick up voltage(Max.) at 23°C	Drop out voltage(Min.) at 23°C	Power consumption at rated voltage
6	125	23.4				
12	62.5	100				
24	31.2	368				
42	17.8	1,188	150 % of rated voltage	80 % of rated voltage	15 % of rated voltage	approx. 0.75VA
48	15.6	1,540				
100/110	7.45	6,880				
110/120	6.8	8,360				
200/220	3.75	26,700				
220/240	3.4	33,000				

»» Specification

Contact material	AgNi / AgSnO alloy	
Contact resistance ⁽¹⁾	100mΩ Max. (1A(100mA for Au-plating contact)/6VDC by 4 pipes mΩ meter)	
Operate time ⁽¹⁾	20ms Max.	
Release time ⁽¹⁾	10ms Max.	
Insulation resistance ⁽¹⁾	1000MΩ Min. (DC 500V)	
Dielectric strength ⁽¹⁾	Between open contact	: AC 1000V, 50/60Hz 1 min.
	Between contact and coil	: AC 5000V, 50/60Hz 1 min.
	Between contact circuits	: AC 3000V, 50/60Hz 1 min. (for 2P DC type) : AC 2500V, 50/60Hz 1 min. (for 2P AC type)
Surge voltage withstand ⁽¹⁾	Between contact and coil	: 10KV (1.2X50)μS
Vibration resistance	Operating extremes	10~55Hz , amplitude 1.5 mm
	Damage limits	10~55Hz , amplitude 1.5 mm
Shock resistance	Operating extremes	10G
	Damage limits	100G
Life expectancy	Mechanical	30,000,000 operations (for DC type) (frequency 72,000 operations /hr)
		10,000,000 operations (for 1P AC type) 5,000,000 operations (for 2P AC type) (frequency 18,000 operations /hr)

SONG CHUAN

507

Life expectancy	Electrical	100,000 operations (frequency 360 operations /hr)
Operating ambient temperature	DC coil	-40~+85°C (no freezing) ⁽²⁾
	AC coil	-40~+70°C (no freezing)
Weight	Approx. 10 g	

Note : (1) Initial value. Operate and release time excluding contact bounce.

(2) Special version of high temperature 105°C can be selected.

» Safety Approval

Certified	UL / CUL	VDE
File No.	E88991	40006746

» Safety Approval Rating (VDE)

◆ DC coil		◆ AC coil		
507H、507HN	507、507N、507N1	507、507N	507H	507
1P		2P		
17A 250VAC T105	12A 250VAC T105	12A 250VAC T85 10A 250VAC T105	17A 250VAC T85	1P: 12A 250VAC T85 2P: 10A 250VAC T85


» Safety Approval Rating (UL/CUL)

507 (1P)		507 (2P)	507N1
AgNi contact	AgSnO contact		
NO/NC: 17A 277VAC	NO/NC: 17A 277VAC	NO/NC: 12A 277VAC	17A 277VAC
NO: 10FLA 250VAC	10FLA 250VAC	NO: 1/2HP 120/240VAC	12A 30VDC
12A 30VDC	1HP 120/240/480VAC	TV-5 (AgSnO contact only)	
1HP 480VAC	NO: TV-8 (for IR type)	NC: 1/3HP 120/240VAC	
NC: 1/2HP 120/240/480VAC	NC: 12A 30VDC		
	1/2HP 120/240/480VAC		


Note : If there is cleaning process and sealed type is selected, the vent-hole should be removed after the process.




» Outline Dimensions

◆ 507 1P







◆ 507H 1P











**◆ 507A 1P****◆ 507 2P****»» Wiring Diagram**

BOTTOM VIEW


◆ 507 1P**◆ 507A 1P****◆ 507H 1P****◆ 507 2P****»» PC Board Layout**

BOTTOM VIEW


◆ 507 1P**◆ 507H 1P****◆ 507A 1P****◆ 507 2P**



Engineering Data




◆ 507 2P




Appendix 3: Pictures

Enclosure – Front View



Enclosure – Rear View




Connectors



Protective earthing terminal




Internal view of inverter




Internal view of inverter (potting)



PCB- Front side



PCB-Rear side



Appendix 4: Test equipment list

Equipment Name	Equipment Number	Manufacturer	Type/Model	Last Cal Date
PV Simulator	EC-7B-LO-PVS-001	CHROMA	62020H-150S	2022/07/31
Grid Simulator	EC-7B-6-PVSR-20211203-002	CHROMA	61815	2022/07/31
RLC Load	EC-7B-ROAD-20211-001	YIMAISI	IMAS5331	2022/07/31
Power analyzer	EC-01-PA-20221115-001	ZLG	PA5000H	2022/08/06
Digital oscilloscope	EC-7B-6-OS-20210419-024	ZLG	ZDS3024Plus	2022/07/30
Digital oscilloscope	EC-7B-OS-20210715-047	Tektronix	C061054	2022/07/31
Multimeter	EC-7B-20-MM-005	FLUKE	17B	2022/07/30
Current Probe	EC-7B-6-CP-20210726-026	CYBERTEK	CP8150A	2022/07/30
Voltage Probe	EC-7B-6-VP-20210726-026	CYBERTEK	P1300	2022/07/30
Temperature / Humidity Chamber	100020200392	YOKOGAWA	GP20	2023/1/6
DC Power supply	EC-7B-6-PVS-20210531-003	CHROMA	62150H-600S	2022/07/31

--- End of test report---