ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. E8A 125178 0001 Rev. 00

Holder of Attestation: **Zhejiang Aiko Solar Technology Co., Ltd.**
No. 655, Haopai Road, Suxi Town
322009 Yiwu, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules (PV Module)**

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 6876024012701

Date, 2024-03-08

(Cookies Bu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. E8A 125178 0001 Rev. 00

Model(s):

For Single-Glass PV module:
Max. System Voltage: up to 1500 VDC (Voc at STC):
With 1/2 cut of mono c-Si cells:
AIKO-Axxx-MAH72Mw (xxx=550-625, in steps of 5, 144 cells)
AIKO-Axxx-MAH60Mw (xxx=460-520, in steps of 5, 120 cells)
AIKO-Axxx-MAH54Mw (xxx=415-465, in steps of 5, 108 cells)
AIKO-Axxx-MAH72Mb (xxx=550-615, in steps of 5, 144 cells)
AIKO-Axxx-MAH60Mb (xxx=460-510, in steps of 5, 120 cells)
AIKO-Axxx-MAH54Mb (xxx=415-460, in steps of 5, 108 cells)
AIKO-Gxxx-MCH72Mw (xxx=615-660, in steps of 5, 144 cells)
AIKO-Gxxx-MCH54Mw (xxx=465-495, in steps of 5, 108 cells)
For Double-Glass PV module (bifacial PV module)
Max. System Voltage: Up to 1500 VDC (Voc at STC):
With 1/2 cut of mono c-Si cells (Under STC):
AIKO-Axxx-MAH72Dw (xxx=585-625, in steps of 5, 144 cells)
AIKO-Axxx-MAH60Dw (xxx=490-520, in steps of 5, 120 cells)
AIKO-Axxx-MAH54Dw (xxx=440-465, in steps of 5, 108 cells)
AIKO-Axxx-MAH72Db (xxx=585-620, in steps of 5, 144 cells)
AIKO-Axxx-MAH60Db (xxx=490-515, in steps of 5, 120 cells)
AIKO-Axxx-MAH54Db (xxx=440-465, in steps of 5, 108 cells)
AIKO-Gxxx-MCH72Dw (xxx=610-650, in steps of 5, 144 cells)
AIKO-Gxxx-MCH54Dw (xxx=460-485, in steps of 5, 108 cells)
With 1/2 cut of mono c-Si cells (Under BNPI):
AIKO-Axxx-MAH72Dw (xxx=615-655, in steps of 5, 144 cells)
AIKO-Axxx-MAH60Dw (xxx=515-545, in steps of 5, 120 cells)
AIKO-Axxx-MAH54Dw (xxx=460-485, in steps of 5, 108 cells)
AIKO-Axxx-MAH72Db (xxx=615-650, in steps of 5, 144 cells)
AIKO-Axxx-MAH60Db (xxx=515-540, in steps of 5, 120 cells)
AIKO-Axxx-MAH54Db (xxx=460-485, in steps of 5, 108 cells)
AIKO-Gxxx-MCH72Dw (xxx=665-705, in steps of 5, 144 cells)
xxx represents output power in Wp

Description of Object:

Rated Input: 45.01VDC, 14.11A, 635W max

Tested according to:

EN IEC 61000-6-1:2019
EN IEC 61000-6-3:2021
EN IEC 61000-6-2:2019
EN IEC 61000-6-4:2019

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®